



- ① VAV 1500-1600 CFM. CONTRACTOR TO PROVIDE & LAY IN REHEAT COILS, SIZED FOR AREA. PIPING WILL BE DON BY FACILITY.
- ② 24X24 LAY-IN 4-WAY SUPPLY GRIDS
- ③ 400 DFM
- ④ 200 CFM
- ⑤ UPSIZE TO HANDLE 800 CMF
- ⑥ 24X24 LAY-IN PERF RETURN GRILLS

# REPLACE EXISTING DUCTWORK FOR PACT REMODEL PROPOSED CONDITIONS