

1. Under section 2.2 SYSTEM COMPONENT REQUIREMENTS: A. Compatibility: a new IDS system Central Station will be "fully compatible"< this can not be achieved as the Lenel has been NIST 800 certified and can not have other systems sharing data (that is not certified) as this would remove the NIST 800 certification, the requirement under 2.5 Control Panel B. "direct connection to an alarm panel" can be met. So the question is do you really need a Central Station as this device would only share data with the Lenel Server and this would not be acceptable?

A Central Station is not required.

2. What is the make and version of the CAD system utilized for this project? AutoCAD 2014
3. With the extensive submittal requirements can the time line for submission be extended? Yes
4. Will after normal business hours work be allowed, if scheduled ahead? Yes