

## **SECTION B** -- Price Cost Schedule of Supplies and Services

The VA Medical Center in Honolulu, Hawaii has a requirement for air filters for its HVAC system. This is a Brand Name or Equal solicitation. The brand name items are Syn-Pac, Tri-Deck, Hepa I, and Hepamax, and the applicable brand names are included in the item descriptions. Those providing name brand quotes must be authorized dealers/distributors/partners of the manufacturer for the items quoted. All items provided by the contractor shall be new, and not used, refurbished, recycled, or in any other form, including substitutions. For quotes, complete the chart below. The salient characteristics are listed below the chart. All Equal items must meet all salient characteristics, otherwise, the quote shall be nonresponsive. Contractors are encouraged to include drawings, descriptions, or any other documents for Equal items quoted.

<b>Item Number</b>	<b>Item Description</b>	<b>Manufacturer's Part Number</b>	<b>Quantity</b>	<b>Unit</b>	<b>Manufacturer's Part Number/ Local Part Number of Item Quoted</b>	<b>Brand Name /Manufacturer of Item Quoted</b>	<b>Unit Price</b>	<b>Extended Price</b>
<b>1</b>	20" x 116" Tri-Deck XL 4 ply link w/at	056201607AT	4	EA				
<b>2</b>	24" x 116" Tri-Deck XL 4 ply link w/at	056241607AT	8	EA				
<b>3</b>	24" x 24" x 15" Syn-Pac 95% 8 pocket	307954415083	38	EA				
<b>4</b>	20" x 20" x 15" Syn-Pac 95% 6 pocket	307950015063	8	EA				
<b>5</b>	20" x 24" x 15" Syn-Pac 95% 5 pocket	307950415053	16	EA				
<b>6</b>	24" x 92" Tri-Deck XL 4 ply link w/at	056241805AT	4	EA				
<b>7</b>	16" x 80" Tri-Deck XL 4 ply link w/at	056162004AT	4	EA				
<b>8</b>	16" x 25" Tri-Deck XL 4 ply panel w/at	050162501AT	6	EA				
<b>9</b>	24" x 24" x 12" Hepa I 99.97% all metal	717112424200	3	EA				



## Section B Price Cost Schedule of Supplies and Services 261-17-Q-0879

<b>10</b>	24" x 24" x 12" HEPAMAX 99.97% up stream all metal	747112424202	1	EA				
<b>11</b>	24" x 24" Tri-Dek XL 4 ply panel w/at	056242401AT	4	EA				
<b>12</b>	14" x 14" Tri-Dek 15/40 3 ply panel w/at	050141401AT	2	EA				
<b>13</b>	16" x 16" Tri-Dek 15/40 3 ply panel w/at	050161601AT	2	EA				
<b>14</b>	20" x 20" Tri-Dek 15/40 3 ply panel w/at	056202001AT	3	EA				
<b>15</b>	16" x 25" Tri-Dek 15/40 3 ply panel w/at	050162501AT	8	EA				
<b>16</b>	20" x 24" x 15" Syn-Pac 80% 5 pocket	307800415053	24	EA				
<b>17</b>	24" x 20" x 15" Syn-Pac 80% 6 pocket	307804015063	1	EA				
<b>18</b>	24" x 24" x 15" Syn-Pac 80% 6 pocket	307804415063	31	EA				
<b>19</b>	24" x 60" Tri-Dek XL 4 ply link w/at	056242003AT	2	EA				
<b>20</b>	12" x 24" x 15" Syn-Pac 85% 4 pocket	307804415063	8	EA				
<b>21</b>	24" x 44" Tri-Dek XL 4 ply link w/at	056241503AT	2	EA				
<b>22</b>	20" x 74" Tri-Dek XL 4 ply link w/at	056202403AT	3	EA				
<b>23</b>	24" x 74" Tri-Dek XL 4 ply link w/at	056242403AT	1	EA				



## Section B Price Cost Schedule of Supplies and Services 261-17-Q-0879

24	20" x 40" Tri-Dek XL 4 ply link w/at	056202002AT	1	EA				
25	20" x 20" x 15" Syn-Pac 80% 6 pocket	307800015063	8	EA				
26	17.5" x 20" Tri-Dek 15/40 3 ply panel w/at	050182001AT	1	EA				
27	24" x 106" Tri-Dek XL 4 ply link w/at	056241507AT	6	EA			\$0.00	\$0.00
28	25" x 60" Tri-Dek XL 4 ply link w/at	056252003AT	2	EA			\$0.00	\$0.00
29	20" x 36" Tri-Dek 15/40 3 ply panel w/at	050203601AT	1	EA			\$0.00	\$0.00

**Extended Total Price:** \$0.00

Brand name or equal HVAC filters must meet the following salient characteristics:

Must be designed to be replaceable,

Must be hospital grade,

Must be anti-microbial,

Must be media dual stage,

Must, at minimum, have a standard 52.2 minimum efficiency reporting value (MERV) 14 (E3, 95% dust spot efficiency),

Must, at minimum, have an extended service life of at least one (1) year,

Must be media dual stage filters,

Must meet American National Standards Institute (ANSI)/Underwriters Laboratories, Inc. (UL) 900 requirements (see

<http://hepafiltersales.com/mm5/graphics/hfs/resources/A-Summerary-of-UL-900-for-HVAC-Air-Filters.pdf> and

[https://standardscatalog.ul.com/standards/en/standard\\_900](https://standardscatalog.ul.com/standards/en/standard_900)) (proof of certification must be provided),

Must provide at least 95 percent filtration, and

Must meet all specifications listed in the item description column of the chart above.