

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	001
PROJECT NAME:	REPLACE Existing Water Tanks, Buildings 1 & 7	DATE REQUESTED:	07/27/2017
SOLICITATION NO.:	VA262-17-B-1247	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Please be specific as possible: Please provide the required water tank capacity of each building [location].			
PROJECT MANAGER'S RESPONSE			
Current water size & capacity: Building 1 – 960 to 1,000 gallons Building 7 – 400 to 500 gallons The total count of sinks, no showers in either building: Building 1 – 49 to 51 sinks Building 7 – 46 to 48 sinks			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: Jorge Guzman / Benny Dillon – COR		DATE: 08/07/2017	