

### APPENDIX 3: MAJOR CHILLERS – HEAT PUMPS

Tag	Type	Location	Area Served	Condition of Equipment	Age	Model Number and or Notes	Manufacturer
200	Air Cooled Chiller for GU Clinic AHU	East of SE PH on 2nd Floor Roof	AHU for GU Clinic	Fair to Good	>10	YCA J110-46PA	York
200	Air Cooled Chiller for AHU-200-1	West of NE PH on 2nd Floor Roof	AHU-200	Good	>7	30RBA08066-NC78C	Carrier
200	Air Cooled Chiller for AHU-200-2	West of SE PH on 2nd Floor Roof	AHU-200	Good	>7	30RBA08066	Carrier
200	Air Cooled Chiller for AHU-200-2	West of SE PH on 2nd Floor Roof	HV-200/	Good	>10	YCAL0040EC46XC	York
200	“Bohn” Air cooled chiller and bundle	East of NW PH on 2nd Floor Roof & D203C	Blood Lab, Cath Lab	Good	>10	30GTN060	Carrier
200	Air Cooled chiller for AC-100	South of NE PH on 1st roof	AC-100	Fair	>10	YCAJ23046PA	York
200	Air Cooled Chiller for Day Surgery	South of NW PH on 1 <sup>st</sup> floor roof	Day Surgery	Good	>3	30RBD15064-1377L	Carrier
200	Air Cooled Chiller for Day Surgery	South of NW PH on 1 <sup>st</sup> floor roof	Day Surgery	Good	>3	30RBD15064-1377L	Carrier
200	Air Cooled Chiller for Acute Surgery	West of SW PH on 2 <sup>nd</sup> floor roof	Acute Surgery	Good	>3	YLAA0080SE46XCA SDXX	Carrier
200	Air Cooled Chiller for Acute Surgery	West of SW PH on 2 <sup>nd</sup> floor roof	Acute Surgery	Good	>3	YLAA0080SE46XCA SDXX	Carrier
200	Air cooled Chiller for Front Lobby	South of NW PH on 1 <sup>st</sup> floor roof	Front Lobby	Good	>3	30RAP0406DAD8F14	Carrier

200	Air cooled Chiller for Front Lobby	South of NW PH on 1 <sup>st</sup> floor roof	Front Lobby	Good	>3	30RAP0406DAD8F14	Carrier
200	Air cooled Chiller for 3 <sup>rd</sup> /4 <sup>th</sup> floor Lobby	NE side of 2 <sup>nd</sup> floor roof	3 <sup>rd</sup> /4 <sup>th</sup> floor Lobby	Good	>10	30GTR050620KJ	Carrier
113	Air Cooled ACCU#3	113 N.	Bldg 113	Good	>7	38AH-084-601FA S/N# 2104F35573	Carrier
113	Air Cooled ACCU #4	113 N.	Bldg 113	Good	>7	38AH-084-601FA S/N# 2104F35581	Carrier
128	Air Cooled ACCU #1	128 N.	Bldg 128	Good	>7	38AH-084-601FA S/N# 2104F35571	Carrier
128	Air Cooled ACCU #2	128 N.	Bldg 128	Good	>7	38AH-084-601FA S/N# 2104F35575	Carrier
217	Air Cooled	Ground level, South unit, CU-1	2 <sup>nd</sup> floor	Excellent	>5	RAUCC604PY03A ODFOOTOO  S/N C06L11140	Trane
217	Air Cooled	Ground level, north unit, CU-2	2 <sup>nd</sup> floor	Excellent	>5	RAUCC604PY03A ODFOOTOO  S/N C06L1141	Trane
217	Air Cooled	Ground level, East unit, Chiller-1	1st Floor	Good	<5	M#30RAP0806D A0Q3C4  S#3713Q79617	Carrier
217	Air Cooled	Ground level, West unit, Chiller-2	1st Floor	Good	<5	M#30RAP0806D A0Q3C4  S#3713Q79625	Carrier
221	Air Cooled	2 <sup>nd</sup> Floor Roof	221	Excellent	>5	30RBB1205CB58--- L  S/N 3510Q74812	Carrier
1	Air Cooled	C-Courtyard West	C436-1 Research	Good	>10	M#-30GB-125- 650AA  S#-4992F26709	Carrier

12	Heat pump/A-C	Bldg. 12 Bsmt WWHP-1	Bldg. 12	Good	>5	M# WW240-4CSN S# 3540-201-000001- T111M47566	FHP
12	Heat pump/A-C	Bldg. 12 Bsmt WWHP-2	Bldg. 12	Good	>5	M# WW240-4CSN S# 3540-201-000002- T111M47566	FHP
12	Heat pump/A-C	Bldg. 12 Bsmt WWHP-3	Bldg. 12	Good	>5	M# WW120-4CSN S# 3540-201-000001- T111M47595	FHP
13	Heat Pump WWHP-1	Bldg. 13 Basement	Bldg. 13	Good	>5	M# UCH070A S# P11744970	Clima-Cool
13	Heat Pump WWHP-2	Bldg. 13 Basement	Bldg. 13	Good	>5	M# UCH070A S# P11744972	Clima-Cool
13	Heat Pump WWHP-3	Bldg. 13 Basement	Bldg. 13	Good	>5	M# UCH070A S# P11643215	Clima-Cool
13	Heat Pump WWHP-4	Bldg. 13 Basement	Bldg. 13	Good	>5	M# UCH070A S# P11744971	Clima-Cool
13	Heat Pump WWHP-6	Bldg. 13 Basement	Bldg. 13 Elevator	Good	>5	M# TTH064AFP S# P11437933	Climate Master
13	Heat Pump WCHP-1	Bldg. 13 Atrium, 1 <sup>st</sup> .	Bldg. 13	Good	>5	M# TLV300AFP S# 11438938	Climate Master
13	Heat Pump WCHP-3	Bldg. 13 Atrium, 1 <sup>st</sup> .	Bldg. 13	Good	>5	M# TTV072AGP S# 11439187	Climate Master
13	Heat Pump WCHP-5	Bldg. 13 Attic	Bldg. 13	Good	>5	M# TSD048A S# P111439130	Climate Master