

RFI FORM

Contractor Name:

Address:

Phone/Fax:

Send to: cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	003
PROJECT NAME:	REPLACE UPS System & INSTALL Rental UPS	DATE REQUESTED:	07/25/2017
SOLICITATION NO.:	VA262-17-B-1183	REFERENCE:	Design-Engineering
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Please be specific as possible: Will the VA provide clarification as to the expected requirements for the “design” portion of this project? Will the VA require an Electrical Engineer stamp on EE prepared drawings? Will the VA require stamped seismic anchoring design documents?			
PROJECT MANAGER’S RESPONSE			
Yes. We will require seismic anchoring design documents. We will require an engineer stamped EE drawing on the UPS installation.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: David Grzechowiak/Maintenance & Operations Chief		DATE: 7/28/17	