QC
INI | %

SHEET NOTES:

1. PLUMBING FIXTURES NOT SHOWN TO HAVE RUNS TO IT.
2. PIPE SIZES NOT KNOWN.

DEAD LEG LOCATIONS:

- 2 (E) 3/4" CW CXC PIPE ABOVE CEILING
- 2 (E) 3/4" HW CXC PIPE ABOVE CEILING
- 2 (E) 3/4" HW CXC PIPE (NO TAG)
- 3 (E) 1 1/4" CW CXC PIPE BED PAN WASH ABANDONED
- 3 (E) 3/4" HW CXC PIPE BED PAN WASH ABANDONED
- 3 (E) 1/2" CW CXC PIPE ABOVE CEILING
- 3 (E) 1/2" HW CXC PIPE ABOVE CEILING

C1294
BUSINESS CENTER C1288
MAIN CHECKIN B1102A
FAAP B1101A
ENTRANCE VESTIBULE B1101
B1100
CORRIDOR B1C01
(E) 3/4" CW
(E) 3/4" HW
(E) 1/2" HWR
(E) 3/4" HWR
(E) 1/2" HW TA
(E) 1/2" CW TA
LIFT C1304
ELECTRICAL C1302
C1301
LAUNDRY B1260
ELEVATOR S8
GOLD ELEVATOR P12
ELEVATOR VESTIBULE B1ESV
ELEVATOR LOBBY B1E00
ELEVATOR S9
GOLD ELEVATOR P11
RETAIL STORE C1300
ELECTRICAL B1259
(E) 1/2" HW TA
(E) 1/2" CW TA
(E) XXX" HW FB
(E) XXX" CW FB
MECH RM G1540
ELEC RM G1541
HW TB
HW TA
(E) 1 1/2" CW
(E) 3/4" HW
(E) 3/4" CW
MECH RM G1542
ELECTRICAL G1542A
4" CW RISER
TELEPHONES G1550
(E) 3/4" HWR
(E) 3/4" HW TA
(E) 3/4" CW TA
(E) XXX" CW TA
ELECTRICAL RM G1543
WOMENS LOCKER G1555
HAC B1258
FMS EQUIP RM B1257
STAIR1 BS1
MENS TOILET B1246
(E) 3/4" HW
(E) 2" CW
STAIR3 BS3
WOMENS TOILET B1245
LOBBY/WAITING B1102
STERILIZER G1544
G1545
OFFICE B1244C
B1244
OFFICE B1244B
OFFICE B1244A
GYN 2 B1242
WOMEN'S HEALTH B1240
CHECKIN B1103
OFFICE B1107
CORRIDOR9 B1C02
(E) 3/4" CW
(E) 3/4" HW
PHARMACY B1109
(E) 3/4" HW
CHECKOUT2
(E) 3/4" CW
(E) 3/4" HW
EXAM RM B1108
EXAM RM B1111
MEDICATION RM B1133
EXAM RM B1110
EXAM RM B1113
EXAM RM B1112
EXAM RM B1135
CORRIDOR B1C03
EXAM RM B1115
PREPARATION RM G1546
(E) 1/2" HW
(E) 1/2" CW
TOILET2 B1242A
GYN1 B1241
CHECKOUT1
OFFICE B1159
EXAM RM B1132
(E) 3/4" HWR
EXAM RM B1161
(E) 3/4" CW
(E) 3/4" HW
EXAM RM B1134
EXAM RM B1137
EXAM RM B1114
EXAM RM B1116
(E) 3/4" CW
(E) 3/4" HW
EXAM RM B1139
EXAM RM B1117
EXAM RM B1136
EXAM RM B1163
CORRIDOR B1C04
EXAM RM B1141
EXAM RM B1118
EXAM RM B1120
(E) 1 1/2" CW
(E) 1" HW
(E) 1" HWR
EXAM RM B1143
REST RM B1143A
EXAM RM B1140
TELE B1167
IT CLOSET B1169
EXAM RM B1142
SPD STORAGE B1122
FMS B1146
EXAM RM B1171
EXAM RM B1148
CONFERENCE RM B1149
(E) 3/4" HW
(E) 3/4" CW
REST RM B1151
STAFF LOUNGE B1150
EKG RM B1180
MENS LOCKER B1150C
WOMENS LOCKER B1150A
WOMENS TOILET B1150B
MENS TOILET B1150D
(E) 1 1/2" CW
(E) 3/4" HW
(E) 3/4" CW
(E) 3/4" HW
STERILE STORAGE G1548
(E) 3/4" CW
(E) 3/4" HW
EXAM RM9 B1217
EXAM RM13 B1186
TREATMENT B1191
EXAM RM B1162
EXAM RM B1164
ELECTRICAL B1165
TELE B1167
CORRIDOR1 B1C06
(E) 1 1/2" HW
(E) 1 1/2" CW
EXAM RM8 B1218
EXAM RM B1193
(E) 3/4" CW
(E) 3/4" HW
EXAM RM B1166
CORRIDOR7 B1C10
EXAM RM B1190
(E) 1 1/4" CW
(E) HB
STORAGE3 B1219
EXAM RM B1195
EXAM RM B1192
EXAM RM14 B1239
(E) 1 1/4" CW
(E) 1 1/4" HW
(E) 3/4" CW
(E) 3/4" HW
DRESS/ TOILET B1166A
EXAM RM B1170
EXAM RM B1172
EXAM RM B1171
EXAM RM7 B1221
STAIR GS2
EMERGENCY GENERATORS BGEN1
(E) 1" CW
(E) 1" HW
(E) 1/2" HWR
OFFICE B1222
STORAGE2 B1220
EXAM RM15 B1237
(E) 3/4" CW
(E) 3/4" HW
EXAM RM B1194
CORRIDOR B1C07
EXAM RM B1196
EXAM RM B1199
EXAM RM B1174
EXAM RM B1201
EXAM RM B1205
(E) 3/4" CW
(E) 3/4" HW
EXAM RM B1175
HAC B1177
CORRIDOR B1C05
SPD STORAGE B1207
REST RM B1179
RIDOR C05
OFFICE K1806
OFFICE K1808
OFFICE K1810
GAS STORAGE BGEN2
EXAM RM16 B1235
TOILET B1223
EXAM RM19 B1238
CORRIDOR6 B1C08
EXAM RM B1198
EXAM RM B1200
EXAM RM20 B1236
EXAM RM17 B1233
JANITOR B1232
EXAM RM18 B1225
RECYCLING B1202
(E) 1 1/2" CW
(E) 3/4" HW
UTILITY STORAGE B1206
EXAM RM6 B1224
(E) 1/2" CW
(E) 1/2" HW
CORRIDOR5 B1C09
OXYGEN B1234
(E) 1" CW
(E) 1" HW
(E) 3/4" CW
(E) 3/4" HW
STAIR2 BS2
OFFICE K1805
OFFICE K1807
OFFICE K1809
CONFERANCE RM B1226
EXAM RM4 B1228
EXAM RM3 B1229
EXAM RM2 B1230
DIETITIAN B1210
CLASS RM B1212
CONFERENCE RM B1214
OFFICE B1216
EXAM RM5 B1227
(E) 1/2" HWR
EXAM RM1 B1231
(E) 3/4" CW
(E) 3/4" HW

FIRST FLOOR EXISTING
PLUMBING FLOOR PLAN

M1.1D