



PARTIAL MECHANICAL FLOOR PLAN  
SCALE: 1/2" = 10'

CODED NOTES:

1. CUT OUT SECTION OF 6" HMM PIPE UPSTREAM OF HEAT EXCHANGERS. PROVIDE TWO 6X6X3" TEES PROVIDE A FULLSIZE BALANCE VALVE WITH MEMORY STOP BETWEEN TEES.
2. CUTOFF AND CAP SECTION OF VENT FROM FLASH TANK. SEE DETAIL.
3. THE 6" VENT FROM EXISTING FLASH TANK INTO BOTTOM OF NEW HEAT EXCHANGERS. PROVIDE 8" VENT FROM TOP OF HEAT EXCHANGER AND TIE IN TO EXISTING VENT.
4. PROVIDE NEW HEAT EXCHANGER. SEE PIPE DIAGRAM FOR MORE DETAILS. PROVIDE HEAT EXCHANGER SUPPORT TO HANG HEAT EXCHANGER.
5. EXISTING VENT UP THRU ROOF.
6. ROUTE 1" LPC FROM BOTTOM OF HEAT EXCHANGER AND TIE INTO CONDENSATE PUMP HEADER WITH A CHECK VALVE AND ISOLATION VALVE.

GENERAL PIPING NOTE:

1. FOR ADDITIONAL INFORMATION SEE PIPING DETAILS ON SHEETS 2-H11 & 2-H14

FULLY SPRINKLERED

Revisions:		Date	
FINAL CD SUBMISSION - FOR CONSTRUCTION		06-18-12	
CONSULTANTS:		ARCHITECT:	
FREDRICK, FREDRICK & HELLER 672 EAST ROXATION ROAD BROADVIEW HTS., OHIO 44147 TEL: (440) 946-4966 FAX: (440) 946-4965		ACC BASEMENT MECHANICAL PLAN	
STATE OF OHIO REGISTERED PROFESSIONAL ENGINEER E-68625 11063		Drawing Title Project Title Location Date Checked Drawn Dwg. of	
VA FORM 08-6231, OCT 1978		VAMC - WADE PARK BMW DAD 2-H6 Office of Facilities Management Department of Veterans Affairs	