PREVENTIVE MAINTENANCE REPORT FOR SCHEDULE NO. EDS-43A
DISTRIBUTION CIRCUIT BREAKERS

JOB NAME:

JOB LOCATION:

JOB NO.: _____ CUBICLE:

Distribution Circuit Breaker #

FRAME SIZE: _____ SENSOR:

CATALOG #_____ SERIAL #

a. Remove drawout breaker, clean and lubricate mechanism.

b. Check all interlocks and auxiliary contacts.

c. Check condition of main and arcing contacts.

d. Clean and lubricate operating mechanism.

e. Check breaker overcurrent trip settings for correct values.

f. Clean interior and exterior of breaker cubicle.

g. Replace breaker and check electrical and manual close and trip operation.

h. Note any unsafe condition, corrective actions, or recommendations if any. None

Distribution Circuit Breaker #

FRAME SIZE: _____ SENSOR:

CATALOG #_____ SERIAL #

a. Remove drawout breaker, clean and lubricate mechanism.

b. Check all interlocks and auxiliary contacts.

c. Check condition of main and arcing contacts.

d. Clean and lubricate operating mechanism.

e. Check breaker overcurrent trip settings for correct values.

f. Clean interior and exterior of breaker cubicle.

g. Replace breaker and check electrical and manual close and trip operation.

h. Note any unsafe condition, corrective actions, or recommendations if any. None

Date Service Performed: _____ Service Engineer: