

RFI FORM**Contractor Name:****Address:****Phone/Fax:****Send to:** cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	011
PROJECT NAME:	MAINTAIN Electrical Power Distribution System	DATE REQUESTED:	08/11/2017
SOLICITATION NO.:	VA262-17-B-1269	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
<p>Please be specific as possible:</p> <ul style="list-style-type: none">- Are oil samples needed?- Minimum transformer (xfmr) and breaker size to test?- Are the ATS included to test?- Are one line wiring diagrams available?- Is there equipment in place to get our equipment to roof since there's no elevator?			
PROJECT MANAGER'S RESPONSE			
<p>Request for Information was submitted / received after the solicitation IFB suspense date / time of Thursday, August 10, 2017 by 1:00PM Pacific local. However, Government (VA) response is as follows:</p> <ul style="list-style-type: none">- No oil sampling required.- Test and inspect only those items on list provided.- ATS's are not included.- See VA response to RFI010 for availability of one line wiring diagrams.- Getting equipment to/from substations or other locations is Contractor responsibility.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: John Gorman, Electronics & Electrical Supervisor		DATE: 08/17/2017	