

**Request for Information**  
**Solicitation No. VA245-17-Q-0223**  
**Clarksburg, WV. Pharmacy IDS**

1. Do the keypads only need to report to the Lenel Head End software or is there a Lynx receiver interface? **System must report to both LENEL and Lynx.**
2. Where is the location of the existing Lenel panels to integrate with the alarm keypads?  
**The LENEL system is connected to the VA LAN.**
3. The General Scope states that the system will be programmed so that each 'area' is its own partition. Please clarify what will be considered an 'area'. Does this mean each protected room? Or a larger 'area' consisting of a building, wing, or floor? **Each protected room.**
4. Can you provide scaled site plans or drawings that show existing the conduit , 'cable chases', or 'tunnel' between buildings? **Scaled drawings are not available.**
5. Will an electronic version of the Response to this RFQ be acceptable by email?  
**Yes**
6. Will there be a public bid opening of the bid?  
**No**
7. How do you want our number submitted to you? We usually use a word doc with numbers and scope of work descriptions.  
**Submission requirements for the quote can be found on pages 13, 14 & 15.**