



GENERAL NOTES

- 1. Measurements/locations are approximate and shall be verified by the Contractor. VA will not be held responsible for any error or variation in any measurements or other data listed.
- 2. Appropriate PPE and safety procedures required.
- 3. ICRA (infection control risk assessment) required prior to starting any work. Follow all ICRA requirements including (but not limited to) providing negative air for work area and bagging debris prior to removal from work area.
- 4. Refer to SOW for additional details/specifications. Reference drawing sheets M-2 for equipment and device schedules. Sheet E-1 shows electrical work guidance.

SHEET NOTES

- ① PROVIDE/INSTALL NEW 40 TON ROOFTOP HVAC UNIT (RTU-1) WITH INSULATED, CUSTOM ADAPTER CURB TO CONNECT TO EXISTING SUPPLY AND RETURN DUCTS. MAINTAIN INTEGRITY AND WARRANTY OF EXISTING ROOF. PROTECT EXISTING EQUIPMENT IN AREA. INSTALL PER MFG INSTRUCTIONS AND SMACNA STANDARDS.

NEW WORK: HVAC EQUIPMENT, DUCTWORK, AND ACCESSORIES

		Approved: Medical Center Facility Manager	Project Title REPLACE RTU-1 B-44		Drawing Title NEW HVAC		Project Number 564-17-133		<div>Engineering Service</div> <div>Department of Veterans Affairs</div>
							Building Number 44		
		Approved: Engineering Service Chief	Measures one inch or not to scale!		Location VAMC - Fayetteville, AR		Drawing Number M-1		
Notes and/or Revisions:			<div>01"NTS</div>		Checked ENG		Date 12 JAN 17		
Date					Drawn ENG		Sheet 2 of 4		