

REQUEST FOR INFORMATION FORM

**SOLICITATION NO. VA245-17-R-0159
PROJECT 688-345
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC**

Submitted By: (Include full name, address and phone number of company) Date: 8/17/17

SAW Contracting, Inc. 2625 Production Rd, Ste A, Virginia Beach, VA 23454, 757-486-1580 x2000

Point of Contact: Anthony Williams

Reference/Subject: Prebid RFI's Parking Garage

Spec.Section No./Title: _____ Page/Art./Para. _____

Drawing No.: A2.4 _____ Plan/Detail/Schedule: _____

Question: (Explain in detail)

The metal screen wall subcontractor has asked:

Will the framing for the screen wall need to be designed and engineered by the metal screen fabricator?

Response:

It is the responsibility of the metal screen fabricator to provide a complete functional product and it includes designing and engineering it properly for its intent. A letter of certification stating that the metal screen will be stable and will perform appropriately as intended will be acceptable in lieu of submitting design calculations.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 21, 2017.