

REQUEST FOR INFORMATION FORM

SOLICITATION NO. VA245-17-R-0159
PROJECT 688-345
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC

Submitted By: Ribeiro Construction Co., Inc.; 301.877.1396
7385-A Old Alexander Ferry Road, Clinton, MD 20735

Date: 17 August 2017

Point of Contact: Cindy Bladen

Reference/Subject: PCI-117 Inclusion

Spec.Section No./Title: 03 45 00-Precast Arch Concrete **Page/Art./Para.**

Drawing No.: **Plan/Detail/Schedule:**

Question: (Explain in detail)

Please clarify the intent of the VA for inclusion of PCI-117 in the RFP.

Response:

The intent is to have acceptable tolerances structurally and architecturally per industry standards.

Thus, the A/E does not think that PCI-117 it is necessary, however it should be included and subsequently reviewed during the submittal process prior to beginning fabrication.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 21, 2017.