

REQUEST FOR INFORMATION FORM

SOLICITATION NO. VA245-17-R-0159
PROJECT 688-345
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC

Submitted By: Ribeiro Construction Co., Inc.; 301.877.1396
7385-A Old Alexander Ferry Road, Clinton, MD 20735

Date: 17 August 2017

Point of Contact: Cindy Bladen

Reference/Subject: SIEMENS Control Panel

Spec.Section No./Title: _____ **Page/Art./Para.** _____

Drawing No.: _____ **Plan/Detail/Schedule:** _____

Question: (Explain in detail)

Is there a Siemens control panel currently monitoring the original FACP in the garage?

Response:

Yes there is an existing Siemens control panel in Building 1 but the existing panel in the garage is incompatible and is being replaced so it can be controlled. Please refer to Specification Section 28 31 11 and drawings.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 21, 2017.