

# **REQUEST FOR INFORMATION FORM**

**SOLICITATION NO. VA245-17-R-0159**  
**PROJECT 688-345**  
**EXPAND VISITOR/ PATIENT PARKING GARAGE**  
**VAMC WASHINGTON, DC**

**Submitted By:** Ribeiro Construction Co., Inc.; 301.877.1396  
7385-A Old Alexander Ferry Road, Clinton, MD 20735

**Date:** 17 August 2017

---

**Point of Contact:** Cindy Bladen

**Reference/Subject:** SIEMENS FACP Tie In

**Spec.Section No./Title:** \_\_\_\_\_ **Page/Art./Para.** \_\_\_\_\_

**Drawing No.:** \_\_\_\_\_ **Plan/Detail/Schedule:** \_\_\_\_\_

---

**Question: (Explain in detail)**

Has a Siemens fire alarm control panel (FACP) been tied into the main control panel in building 1 for the Parking Garage?

**Response:**

The existing FACP in the garage is incompatible with the Siemens campus wide system and that is why it is being replaced as part of this project. Please refer to Specification Section 28 31 11 and drawings.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, [Robert.perry2@va.gov](mailto:Robert.perry2@va.gov) OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 21, 2017.