

REQUEST FOR INFORMATION FORM

SOLICITATION NO. VA245-17-R-0159
PROJECT 688-345
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC

Submitted By: Ribeiro Construction Co., Inc.; 301.877.1396
7385-A Old Alexander Ferry Road, Clinton, MD 20735

Date: 17 August 2017

Point of Contact: Cindy Bladen

Reference/Subject: Access Gate Override Switch Path

Spec.Section No./Title: _____ **Page/Art./Para.** _____

Drawing No.: E2.6 **Plan/Detail/Schedule:** _____

Question: (Explain in detail)

If the security office intended to house the access gate override switch shown on the ACCESS GATE WIRE DIAGRAM on sheet E2.6 of the bid documents is other than the small guard booth that sets in the center of the street directly across from this gate arm, then please clarify and provide the intended path for the feed.

Response:

Design intent is for it to be located in the Viewing Booth 301 in the garage. See drawing A1.1.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 21, 2017.