

REQUEST FOR INFORMATION FORM

SOLICITATION NO. VA245-17-R-0159
PROJECT 688-345
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC

Submitted By: Ribeiro Construction Co., Inc.; 301.877.1396
7385-A Old Alexander Ferry Road, Clinton, MD 20735

Date: 17 August 2017

Point of Contact: Cindy Bladen

Reference/Subject: Card Reader System

Spec.Section No./Title: 28 13 00 **Page/Art./Para.**

Drawing No.: **Plan/Detail/Schedule:**

Question: (Explain in detail)

Is it the design intent for the DCVAMC hospital's Security system vendor to provide the magnetic door power supplies, locks and switches for the access control card reader system?

Response:

Security vendor shall provide the interface with the existing access control system and all of the hardware and cables specified in section 28 13 00 - Physical Access Control. Builder's hardware including electrified locksets are specified in section 08 71 00 – Door Hardware. Power supplies for electric hardware and cable to electric hardware is part of this work. Automatic door operators are specified in in section 08 71 73 - Automatic Door Operators. Power supplies, cable, and interface with the electrified hardware is part of this work.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 21, 2017.