

three inches = one foot

one and one half inches = one foot

one inch = one foot

three quarters inch = one foot

one half inch = one foot

three eighths inch = one foot

one quarter inch = one foot

one eighth inch = one foot

DRAWING NOTES:

- 1 VENT SHALL BE A MINIMUM OF ONE PIPE SIZE LARGER THAN SAFETY VALVE OUTLET. FINAL VALVE SIZE SHALL BE BY THE MANUFACTURER. CONTRACTOR SHALL FURNISH AND INSTALL DRIP PAN ELBOW.
- 2 FINAL VENT SIZE SHALL BE BY THE MANUFACTURER.
- 3 VALVE LOCKABLE IN OPEN POSITION ONLY.

DEAERATOR/FEEDWATER SYSTEM SCHEMATIC

FINAL DESIGN
APPROVED FOR CONSTRUCTION

CONSULTANTS:

AEI Affiliated Engineers
Affiliated Engineers SE, Inc.
Trioga Town Center
12921 SW 1st Road Ste 205
Gainesville, Florida 32609
Tel 352.376.5500 Fax 352.375.3479
CA-6140

ENGINEER-OF-RECORD

JACK STEWART NEALE

FL P.E. NO.

42678

ARCHITECT/ENGINEERS:

AKEA INC.
3603 NW 98th Street, Suite B
Gainesville, FL 32606
Phone: (352) 474-6124
Fax: (352) 553-4437
COA: FL #26693
AKEA Project No. 083-14

Drawing Title

DEAERATOR/FEEDWATER SYSTEM
SCHEMATIC

Approved: Project Director

Project Title

REPLACE BOILERS - FCA D, ENERGY
AT THE MALCOM RANDALL VAMC

Location

GAINESVILLE, FLORIDA

Date

JULY 8, 2016

Checked

JSN

Drawn

RWD

Project Number

573-14-600

Building Number

Drawing Number

MP703

Office of
Construction
and Facilities
Management

