

- 1 ROUTE FUEL OIL PIPING BELOW GRADE TO NEW BOILER BUILDING. TOP OF PIPE TO BE A MINIMUM OF 36" BELOW GRADE.
- 2 REFER TO NEW BOILER BUILDING PLANS FOR CONTINUATION.
- 3 WATER TIGHT SUMP FOR ACCESS TO LEAK DETECTION SENSORS MAXIMUM SPACING 100 FT. REFER TO SPEC SECTION 231000.
- 4 3" FOS AND 2" FOR.
- 5 SPILL CONTAINMENT MAN HOLE (FUEL OIL FILL).
- 6 CONCRETE PAD ON GRADE WITH MANHOLE COVER.
- 7 DOUBLE WALL CONTAINMENT.



Department of  
Veterans Affairs