

REQUEST FOR INFORMATION FORM

SOLICITATION NO. VA245-17-R-0159
PROJECT 688-345
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC

Submitted By: Ribeiro Construction Co., Inc.; 301.877.1396
7385-A Old Alexander Ferry Road, Clinton, MD 20735

Date: 17 August 2017

Point of Contact: Cindy Bladen

Reference/Subject: Barrier Cable System

Spec.Section No./Title: _____

Page/Art./Para. _____

Drawing No.: A2.4

Plan/Detail/Schedule: _____

Question: (Explain in detail)

Is the Parking Garage BARRIER CABLE SYSTEM a requirement of the Precast Manufacture?

Response:

The barrier cable system is a functional requirement from the VA patient safety standards.
The contractor is responsible for providing the Barrier Cable System.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR
BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 21, 2017.