


Explanation:

- 2B40 Room Numbers
- xxx Asbestos Sample Locations And Numbers
- Asbestos-containing Floor Tile
- Asbestos-containing Floor Tile And Black Mastic
- Asbestos-containing Floor Tile And Black Mastic Under Glued-down Carpet
- Asbestos-containing ceramic tile (Assumed)

Note : Black Floor Mastic is ACM

**George E. Wahlen Department of Veterans
 Affairs Medical Center
 Salt Lake City, Utah 84148**

Limited Asbestos Material Survey : Building 14 (First Level)



PROJECT No:	14950.01
SHEET:	3
DRAWN BY:	S. Rahman
DATE:	11-12-10
REVISED BY:	Tom
DATE:	2-17-2017
REVIEWED BY:	
DATE:	