

**RFI FORM**

**Contractor Name:**

**Address:**

**Phone/Fax:**

**Send to:** [cecil.nichols@va.gov](mailto:cecil.nichols@va.gov)

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>		<b>RFI NO.:</b>	015
<b>PROJECT NAME:</b>	REPAIR Existing Roof and INSTALL Doors & Canopy, Building 46	<b>DATE REQUESTED:</b>	09/12/2017
<b>SOLICITATION NO.:</b>	VA262-17-B-1481	<b>REFERENCE:</b>	roofing
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible: Clarification to Amendment A00003:  On the new specification for roofing of maintenance shed, VA only provided GAF 30#... we need a specification reference like 4GNC this would be a fiberglass base sheet nailed to two (2) layers of 11# ply mopped and one (1) layer of regular cap sheet not title 24 because this area is not air conditioned space.			
<b>PROJECT MANAGER'S RESPONSE</b>			
Roofing is to be hot mopped with 30 lbs felt; see specification section 075100 on the TIL website – <a href="http://www.cfm.va.gov/TIL">www.cfm.va.gov/TIL</a>			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>  Benny Dillon & Keith Didrickson / VA CORs		<b>DATE:</b>  9/12/2017	