

Current Rm Name/No.	Surface	Material	Size	Color	Sample Info				HAZARD ASSESSMENT								COMMENT
					Asbestos Present	PreviouslyS ampled (Y/N)	Contractor Sampled?	Contractor Sample No.	Friable	Good - No Damage	Damaged (10% overall or 25% localized)	SignificantlyDamaged >10% overall OR >25% localized)	Potential for Damage (vibration, Access, Erosion)	TSI	Surfacing	Misc	
2	Ceiling	Acoustic Ceiling Tile Pinhole Big Worm	2x4		N	Y	N	N	Friable	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Plaster	900 SF	Off White	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Resilient Floor Tile with Mastic	12x12	White with Grey	N	N	Y	VALB-136- F2.3	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Door/Door Frame	Wood/Metal		Beige/Beige	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Cove Base with Glue	4"	Off White	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Concrete		Concrete	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Fire Stop			N	N	Y	VALB-136- M1.1	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Kitchen	Ceiling	Acoustic Ceiling Tile Pinhole Big Worm	2x4		N	Y	N	N	Friable	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Plaster	900 SF	Off White	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Resilient Floor Tile with Mastic	12x12	White with Grey	N	N	Y	VALB-136- F2.3	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Door/Door Frame	Wood/Metal		Beige/Beige	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Cove Base with Glue	4"	Off White	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Concrete		Concrete	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Fire Stop			N	N	Y	VALB-136- M1.1	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4	Ceiling	Acoustic Ceiling Tile Pinhole Big Worm	2x4		N	Y	N	N	Friable	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Plaster	900 SF	Off White	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Resilient Floor Tile with Mastic	12x12	White with Grey	N	N	Y	VALB-136- F2.3	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Door/Door Frame	Wood/Metal		Beige/Beige	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Cove Base with Glue	4"	Off White	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Concrete		Concrete	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Fire Stop			N	N	Y	VALB-136- M1.1	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
136A	Ceiling	Acoustic Ceiling Tile Pinhole Worm	2x2		N	Y	N	N	Friable	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Plaster		Off White	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Resilient Floor Tile with Mastic	12x12	Tan	N	N	Y	VALB-136- F1.1-F1.3	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Door/Door Frame	Wood/Metal		Beige/Beige	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Cove Base with Mastic	4"	Beige/Tan	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Resilient Floor Tile with Mastic	12x12	White	N	N	Y	VALB-136- F2.1-F2.3	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mens	Ceiling	Acoustic Ceiling Tile Pinhole Big Worm	2x4		N	Y	N	N	Friable	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Plaster	12x12	Off White	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Ceramic Tile and Grout	1x1	Yellow	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Door/Door Frame	Wood/Metal		Brown/Brown	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Current Rm Name/No.	Surface	Material	Size	Color	Sample Info				HAZARD ASSESSMENT								COMMENT
					Asbestos Present	PreviouslyS ampled (Y/N)	Contractor Sampled?	Contractor Sample No.	Friable	Good - No Damage	Damaged (10% overall or 25% localized)	SignificantlyDamaged >10% overall OR >25% localized)	Potential for Damage (vibration, Access, Erosion)	TSI	Surfacing	Misc	
Women's	Ceiling	Acoustic Ceiling Tile Pinhole Big Worm			N	Y	N	N	Friable	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Plaster	12x12	Off White	N	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Ceramic Tile and Grout		Yellow	Not Suspect	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Door/Door Frame	Wood/Metal		Brown/Brown	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Ceramic Tile and grout	4x4	Yellow	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Concrete		Off White	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Exterior	Wall(s)	Stucco		Beige	Y (Trace)	Y	N	N	N	FAIR	X	N/A	X	N/A	N/A	X	SAMPLE NOT POINT COUNTED
	Misc	Window Metal		Silver	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Window Sealant	16 LF x 1/2"	Black	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Janitor Closet	Ceiling	Concrete		Off White	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Concrete	12x12	Off White	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Concrete		Bare	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Door/Door Frame	Metal/Metal		Beige/Beige	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	TSI Fitting	6"	White	N	Y	N	N	Friable	Y	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Fire Stop		Red	N	N	Y	M1.1-M1.3	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Misc	Thermal System Insulation		Gray	Y (3%)	Y	N	N	Friable	Y	N/A	N/A	X	X	N/A	N/A	LIKELY ADDITIONAL TSI THAT IS CONCEALED
Roof	Ceiling	Sealed Roof System		White	N	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Roof Tar Over Vent	25 SF	Black	Y (5%)	Y	N	N	Friable	N	N/A	N/A	N/A	N/A	N/A	X	UNDER WHITE CAP SHEET
	Misc	Low Roof at Parapet Flashing		Black	Y (7%)	Y	N	N	Friable	N	N/A	N/A	N/A	N/A	N/A	X	UNDER WHITE CAP SHEET
Wood Shed	Ceiling	Wood		Bare	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Wood		Bare	Not Suspect	Y	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Floor	Concrete		Bare	N	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Door/Door Frame	Wood		Bare	Not Suspect	N	N	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Wood Shed Roof	Ceiling	Shingles		Brown	N	N	Y	R1.1-R1.3	N	Y	N/A	N/A	N/A	N/A	N/A	N/A	
	Wall(s)	Felt Paper		Black	N	N	Y	R2.1-R2.3	N	Y	N/A	N/A	N/A	N/A	N/A	N/A	