

# **Powerlogics, Inc.**

**PROJECT**  
**Infrared Testing**  
**Job #13-320**

**Location**  
**Malcom Randall VA Medical Center**  
**1601 SW Archer Road**  
**Gainesville, FL 32608**

**Report Prepared by:**

**Electrical Testing Incorporated**  
**2671 Cedartown Highway SE**  
**Rome, GA 30161**  
**Telephone (706) 234-7623 Fax (706) 236-9028**





**ELECTRICAL TESTING, INC.**  
2671 Cedartown Hwy. – Rome, GA 30161  
Telephone 706-234-7623 – Fax 706-236-9028  
E-Mail eti@electricaltestinginc.com



## **Malcom Randall VA Medical Center Infrared Equipment List December 2, 2013**

The following equipment was inspected and no apparent discrepancies were found.

### **BASEMENT**

#### **Room EB65-1**

Cat Scan RM E195  
Transformer T-7  
Panel FPR  
Panel FPE6  
Switchgear #7  
ATS-Q2  
Switchgear T-6  
Panel FPE-5  
ATS E2  
600 KW Tie Breaker #5 1000Amp  
ATS-E  
ATS-Q  
ATS-C  
ATS-TS-C2

#### **Sub Basement**

Panel CVL  
Transformer CDH

#### **Fenced Area Behind Gen. Building**

Panel LCI  
Panel XLA  
New Panel

#### **Building 23**

Panel 120/208

**Room CO78-1**

Disconnect MFP 11  
Disconnect MFP 10  
Disconnect MFP 9  
Disconnect P-16  
Disconnect P-17  
Disconnect P-18  
Panel NP-1A  
30kV Transformer  
Transformer PBCQ1  
Panel CULMIA  
House Pump #1  
House Pump #2  
House Pump #3  
Pump P-6  
Pump P-7  
Pump P-8  
Disconnect Condensate Station  
Sump Pump #1  
Sump Pump #2  
Ch. W P-3 VFD

**Room CO78A-1**

Disconnect Main Power Supply #1 Boiler  
Disconnect Main Power Supply #2 Boiler  
Disconnect Main Power Supply #3 Boiler

**Room CO90-1**

MCC-M1  
MCC-M2  
Disconnect EF-19  
I-CCU1  
I-CCU2  
C.W. P-3 VFD  
CWP 4  
CWP 5  
CWP 6  
CT2-3 VFD  
CT2-2 VFD  
CT2-1 VFD  
CT1-3 VFD  
CT1-2 VFD  
CT1-1 VFD  
Chiller #1 VFD  
Chiller #2 VFD

Chiller #3 VFD  
 Chiller #4 VFD  
 Panel PBCQA  
 Panel PBCQB Sect. #1  
 Panel PBCQB Sect. #2  
 Panel PBCQ1  
 Panel PBCNA Sect. #1  
 Panel PBCNA Sect. #2  
 Starter PP-6  
 Starter PP-7  
 Starter P-1  
 Starter T-2  
 Panel PBCQC  
 Disconnect P-20  
 Disconnect P-21  
 CT-3 VFD  
 CT-4 VFD  
 CT-5 VFD  
 CWP-2  
 Disconnect E8

### **Garage**

Panel ATS-1  
 Panel ATS-2  
 Panel ATS-3  
 Panel ELP-1  
 Panel TLCP  
 Panel LCP  
 Panel LP1  
 Panel MDP  
 Panel LA  
 Panel ELA  
 Panel EDP  
 Panel ELVDP ( 5<sup>th</sup> Floor)

### **New Garage**

Panel MDP2  
 Panel ALA2 TX  
 Panel EDP2  
 Panel ATS-4  
 Panel ATS-5  
 Pane; ATS-6  
 Panel ELP2  
 Panel TLCP2  
 Panel LCP2  
 Panel LP2

Panel LCP2 TX  
Panel T2

**Full Power Building**

Panel GI  
Panel GA

**Room CO73-1**

Disconnect UC8  
Disconnect UC2  
Disconnect UC3  
Disconnect UC4  
Disconnect UC5  
Disconnect UC7  
Disconnect UC9B  
Disconnect UC10  
Disconnect UC12  
Disconnect UC13  
Disconnect UC9A  
Disconnect UC11  
Disconnect UC6  
Disconnect UC15  
Disconnect UC1  
Panel SKH-CO73-BC  
Panel SKL-4

**Room CO92-1**

Switchgear US-9  
Switchgear US-8  
Panel MLGA  
Transformer MPGA  
Panel MPGA  
Panel EMDP-4  
ATS MEP LSI  
Panel ELLA  
Panel MEP ELPA  
ATS MEP CI  
Panel MEP ECLA  
Transformer ECPA  
Panel ECPA  
ATS MEP EQ2  
Panel MEP EELA  
ATS MEP EQ3  
Panel MEP EELB

Panel P4  
Panel P5  
Panel P6  
Panel MLGA  
Switchgear US10  
Panel DP2CH  
Panel DP1CH

**Room CO85**

Panel VFD AC-1  
Panel FAN T-1  
Panel OLH-1-BC  
Disconnect #1  
Disconnect #2  
Disconnect #3

**New Electrical Room**

Panel BC.N.DPA  
Panel BC.CRZ.DLB  
Panel BC.N.DPI  
Panel TX-BC.N.DPZ  
Panel BC.N.DPZ  
Panel BC.LS.DZA  
Panel BC.N.DPB  
Panel BC.CR3.DPB  
Panel BC.CR3.DPA  
Panel BC.N.PI  
Panel BC.CR3.PA

**Room SP203**

Panel D-ECH  
Panel E-ECH  
Panel G-ECC  
Panel B-C  
Panel Trans A  
Panel M-DP  
Panel A-H  
Bed Tower Generator  
Panel LIISG

**Building #25**

ATS-1  
Panel CP-1  
Transformer PP-1

Disconnect North Gear  
Disconnect South Gear

**Room FB30-1**

Main Switchgear US-5  
Main Switchgear US-4  
ATS LS2  
Disconnect ESLSDP2  
ATS C2  
Disconnect ASCDP2  
ATS EQ2  
Disconnect ESEQDP-2  
Switchgear EMDP-2  
Switchgear EMDP-1  
ATS LS1  
Disconnect ESLSDP1  
ATS C1  
Disconnect ESCDPI  
ATS EQ1  
Disconnect ESEQDPI  
ATS EQ3B  
Disconnect ESEQDP3  
ATS EQ3C  
Disconnect ESEQDP4

**Room FB-29-1**

VFD I-RF1  
VFD I-SF1  
VFD I-RF2  
VFD I-SF2  
VFD I-RF3  
VFD I-SF3  
VFD I-RF4  
VFD I-SF4  
MCC-GA  
MCC-GB  
Disconnect IEF1  
Disconnect I-HE3  
Disconnect I-HE2  
Disconnect I-HE1  
Disconnect I-TAC2  
VFD I-P10  
VFD I-P9

**Room B184-1**

Panel EQ1

**Room FB28J-1**

Panel AECLGB  
Panel AEELGB  
Panel AELLGB  
Panel AELPGB  
Panel AECPGB  
Panel APGD  
Panel APGC  
Panel APGB  
Transformer APGC  
Transformer APGD  
Transformer AELPGB

**Room EC-EB-61-1**

Panel E4BB  
Panel E2BB  
Panel L4BB  
Panel L2BB Sect. #1  
Panel L2BB Sect. #2  
Transformer EBB  
Transformer BB  
Transformer L2BB1

**Room EC-EB-08-1**

Panel E4BA  
Panel E2BA  
Panel L4BA  
Panel L2BA Sect. #1  
Panel L2BA Sect. #2  
Panel L2BA Sect. #3  
Transformer EBA  
Transformer BA

**Room FB-20-1**

Panel AECLGA  
Panel AEELGA  
Panel AELLGA  
Panel AELPGA  
Panel AECPGA  
Panel APGA

Panel APGB  
Panel ALGA  
Transformer AELPGA  
Transformer APGA  
Transformer APGB

**Education Building**

Panel L2  
Panel L1  
Panel LD

**New Electrical Room for Hospital**

Panel BC.N.DCA  
Panel BC.CRZ.DLA  
Panel BD.LS.LI  
Panel PBD.QA  
Panel PBD.LA  
Panel PBD.CC  
Panel PBD.CB  
Panel PBD.CI  
Panel PBD.CA  
Panel PBD.NI  
Panel PBD.NA  
Switchgear MSGR-B  
Switchgear MSGR-A  
Switchgear DC Panel 1  
Switchgear EMSBD1  
Switchgear ATS-LS  
Switchgear ATS-EC1  
Switchgear ATS-EC2  
Switchgear ATS-EC3  
Switchgear ATS STBY 1  
Switchgear ATS-EQ2  
Switchgear ATS-EQ1  
Transformer A TX-MSGR-A  
Transformer B TX-MSGR-B

**Room EB47-1**

Panel P2BAR  
Panel L4BAR  
Panel C4BAR  
Panel CP2BAR  
Transformer BAR  
Transformer CBAR

**Room EC-DO93A**

Panel BNDP  
Panel CLH-3-BD  
Panel UL-3-BD Sect. #1  
Panel UL-3-BD Sect. #2  
Panel DH-3-BD  
Panel CDH-3-BD Sect. #1  
Panel CDH-3-BD Sect. #2  
Panel EDH-3-BD  
Transformer 17  
Transformer 10  
CDL Sub Panel

**Room CO58-1 (Kitchen)**

Panel SKDH-5-BB  
Disconnect #1  
Main Kitchen  
Panel SKH1-CO68-BC  
Panel SKH-BO68I-BC  
Panel SKL-BO68I-BB

**Room SPF800**

Panel AECPGC  
Disconnect P11  
Disconnect P12

**Room A-013-1**

Panel P8-B

**Room A-012**

Panel P8-A

**Room CO58-1**

Panel SKL2-BO68I-BB  
Panel SKH2-BO68I-BB  
Panel CUL-BO54-BB  
Disconnect Dishwasher

**Room BO54G-1**

Panel 2C-1-BB  
Panel CLL-1-BB

Panel UL-1-BB Sect. #1  
Panel UL-1-BB Sect. #2  
Panel CLH-1-BB  
Disconnect Transformer #3  
Transformer #3  
Retail Store Closet  
Panel CRSP  
Panel RSL  
Panel RSPA  
Disconnect CLBB2  
Disconnect Compressor  
Transformer RSPA  
Transformer CLBB2

**Room EB60-1**

MCC-Q  
MCC-N  
Panel C4MR  
Panel PQ-4  
Panel C2MR  
Transformer CMR  
Disconnect Pump #1  
Disconnect Pump #2  
Disconnect Pump #3  
Dom. Water BST. Pump  
Disconnect CP-#3  
Disconnect CP-#2  
ORAL EVAC. Equipment  
MCCE-2  
Disconnect from MCCE-2  
Disconnect CAC #1  
Disconnect CAC #2  
Disconnect AC-4E  
Panel 4E  
BALDOR Starter  
Hallway BO49I-1  
Panel CLBB1 Sect. #1  
Panel CLBB1 Sect. #2  
Panel CHBB  
Panel CLBB2

**X-Ray Room 305**

Panel C 29-7

**Room SP101A-1**

Pool Panel 1  
Disconnect #1  
Disconnect #2 (Square D)  
Transformer #1  
A-C1 Building #2  
Panel CUL-M2  
Disconnect Transformer 40  
MCC-PH2

**Room AO26C-1**

Panel CLH-2-BA  
Panel CLL-2-BA  
Panel UL-2-BA Sect. #1  
Panel UL-2-BA Sect. #2  
Panel ELH-2-BA  
Panel DH-2-BA  
Panel EDH-2-BA  
Panel CDH-2-BA  
Panel EUL-2-BA  
(NEW) Panel  
Transformer T71  
Transformer 29  
Disconnect Stage Dimmer

**Room D120-1**

Panel CDL-D120-BD Sect. #1  
Panel CDL-D120-BD Sect. #2  
Panel CUL-D120-BD Sect. #1  
Panel CUL-D120-BD Sect. #2  
Panel CDL-3A-BD  
Disconnect CUL0-D101-BD  
Disconnect Distillers-D122  
Disconnect T18 Main Breaker  
Disconnect (Square D)  
Disconnect T-70  
Transformer T-70  
Transformer T-18

**Room D116-1**

Panel P-3

**Room D121-1**

Panel P-1

**Room D124-1**

Panel P-1A

**Room A06**

Panel P-9

**Room A016**

Panel P-9A

**Room A020-1**

Panel CPH-A020-BA

**Room A023-1**

Panel P-18

**Room A060A-1**

Panel #1

**Room D104-1**

Panel P-4

**Room D110-1**

Panel CUL-D110-BD

**Room EB 80-1**

Panel C2-Z

**Room A02-1**

Panel P-7

**Room A 18-1**

Panel P-18

**Hall**

Panel L2 R1  
Panel C2 R1

**Room A027-1**

Panel A027

**Tunnel SB**

Panel S  
Panel S1

**Room D105-1**

Panel P-5

**Room D100-1**

Panel BHDA  
Panel BNPA Sect. #1  
Panel BNPA Sect. #2  
Research Lab  
Panel L2R1  
Panel C2R1

**Room EB87-1 (Engineering)**

Panel L2BBA

**Room C283-B**

Panel CLH51C  
Panel CUL-5-1C  
Panel EH-1  
Panel UL-5-1C Sect. #1  
Panel UL-5-1C Sect. #2  
Panel CUL-5-1C  
Disconnect Transformer #5  
Disconnect Transformer #4  
Transformer #5  
Transformer #4

**Room D166-1**

Panel CLH 31D  
Panel CLL 31D Sect. #1

Panel CLL 31D Sect. #2  
Panel CLL 31D Sect. #3  
Panel ELH-3-ID  
Panel UL-3-ID Sect. #1  
Panel UL-3-ID Sect. #2  
Panel INDP  
Disconnect Transformer.20 #1  
Disconnect Transformer.20 #2  
Disconnect Transformer.21  
Transformer 20  
Transformer 21  
Transformer 11

**Room B229A**

Panel 1 B.CR3.P2  
Panel 1 B.CR3.PA  
Panel UL-1-1B Sect. #1  
Panel UL-1-1B Sect. #2  
Panel SPE 169  
Panel LLIP 1  
Panel E41  
Panel E21B  
Panel C21B  
Panel TX C1B  
Panel C41B  
Panel L41B  
Panel L21B  
Panel S41B  
Panel A1  
Panel ORUPS

**Room E155-1**

Panel C4IA  
Panel C2IA  
Panel E2IA  
Panel E4IA  
Panel LS4IA  
Panel C2IC  
Panel C4IC  
Panel L2IAA  
Panel L2IA  
Panel L4IA  
Disconnect ER Canopy Lights  
Transformer EIA  
Transformer LIA

Transformer L2IC  
Transformer 1A  
Transformer 1AA

**Room F137-1**

Panel AELP1A  
Panel ALIA  
Panel AECLIA  
Panel AECPIA  
Panel AEEPIA  
Panel APIB  
Panel APIA  
Transformer AECPIA  
Transformer AEEPIA  
Transformer APIA  
Transformer APIB  
Contactor LC-I

**Room G163-1**

Panel ALIB  
Panel APIC  
Panel APID  
Panel AECPIB  
Panel AECLIB  
Transformer APID  
Transformer APIC  
Transformer AECPIB  
Disconnect X-Ray Equipment Room

**Room E-126**

Panel UP5  
Panel L2L1  
Panel C2L1  
Panel C2L2 Sect. #1  
Panel C2L2 Sect. #2  
Panel L2C2

**Room EC 118-1**

Panel L4IAL  
Panel C4IAL  
Panel P2IAL  
Transformer C1AL  
Transformer 1AL  
Starter EF14

Starter EF13  
Starter EF12  
Starter EF11  
Starter EF10  
Starter EF7  
Starter EF9  
Starter EF15  
Starter EF8  
Disconnect EF16E  
Panel E126-1  
Panel C2L2  
Panel L2L2  
Panel C2L2 Sub Panel 2  
Panel L2L1  
Panel C2L1

**Room D314A-1**

Panel DCRPI

**Room D334-1**

Panel ICPA

**Room D330-1**

Panel INPD

**Room A164-1**

Panel IHLA  
Panel INPA  
Panel CLL-3-ID Sect. 2A

**Room A16**

Panel VL2IA Sect. #1  
Panel VL2IA Sect. #2  
Panel CLH-2-IA

**ER Closet**

Panel 1

**Room 316-1**

Panel INPD

**Room D311**

Panel CLH-31-A  
Panel CL3A-1B

**Room D305**

Panel 305

**Room D308**

Panel 308

**Room E194**

Panel 194

**Room E195**

PQ 6000

**Hall at D339**

Panel CLL3-ID-3

**Room C246-1**

Heart Cath Panel  
Panel IPU 8

**Room B215-1**

Panel UL-1-IB

**Room A134-1**

Panel CLL-2-IA

**Room C297-1**

Panel CULXI-C297-IC  
Disconnect Transformer 39  
Disconnect Transformer 38  
Hall Beside Room A-267-1  
Panel UL2D Sect. #1  
Panel UL2D Sect. #2  
Panel UL2D Sect. #3  
Panel CUL-3-2D

Panel CLL-3-2D  
 Disconnect Transformer 23  
 Disconnect Transformer 22  
 Transformer 23  
 Transformer 22

**Room A211A-1**

Panel CUL-2-2A  
 Panel UL-2-2A Sect. #1  
 Panel UL-2-2A Sect. #2  
 Panel UL-2-2A Sect. #3  
 Transformer 33  
 Transformer 32  
 Disconnect Transformer 33  
 Disconnect Transformer 32  
 Hall Between B290-1 and A289-1  
 Panel LH-I-2B

**Room B237**

Panel UL-I-2B Sect. #1  
 Panel UL-I-2B Sect. #2

**Room E258-1**

Panel 2NPDA  
 Panel 2NPA  
 Panel 2 NPB Sect. #1  
 Panel 2 NPB Sect. #2  
 Panel 2NPD  
 Panel 2CPA-IA  
 Panel 2HLA  
 Panel 2CPA  
 Contactor Panel  
 Transformer TC-1  
 Transformer T-1  
 Disconnect N-3  
 Disconnect N-2  
 Disconnect N-1  
 Disconnect EM-1  
 NF-2 Buss Tap-Can  
 EF-2 Buss Tap-Can

**Room EC E202-1**

Panel 2NPE  
 Panel 2NPF

Panel 2NPDB  
 Disconnect N-10  
 Disconnect N-9  
 Disconnect N-8  
 Transformer T-2

**Room E207-1**

Disconnect A/C Unit-GV  
 Disconnect AC-2 (RAF)  
 Disconnect AC-3E (SAF)  
 Disconnect 60 Amp ITE  
 Disconnect AHU #1  
 Disconnect AHU #2  
 Disconnect AHU #3  
 Disconnect REG #1  
 Disconnect REG #2  
 Disconnect OAF #1  
 Disconnect OAF #2  
 Disconnect EF #1  
 Disconnect EF #2  
 VFD E-Wing

**Room E207-1**

Disconnect RAF #1  
 Disconnect RAF #2  
 Square D Contactor #1  
 Square D Contactor #2

**2<sup>nd</sup> Floor Penthouse**

Panel AEPP2A  
 Panel AL2A  
 Panel AP2A  
 Panel I-HE1  
 Disconnect 1-AH7  
 MCC-2A  
 VFD I-SF1  
 VFD I-RF1  
 VFD I-EF6  
 VFD I-SF6  
 Transformer AP2A  
 Disconnect #1

**2<sup>nd</sup> Floor Roof**

AC Unit 1-ACRCUI

Disconnect Vent 1  
Disconnect Vent 2  
Disconnect AC Units 1-6

**THIRD FLOOR**

**Room E302-1**

Panel 3NPF  
Panel 3NPJ  
Panel 3CPB  
Panel 3NPDB  
Transformer T-4  
Disconnect N-11

**Room E356-1**

Panel 3NPDA  
Panel 3NPC  
Panel 3NPI  
Panel 3LSA  
Panel 3HLA  
Panel CPA  
Panel 3CHA  
Transformer TC-2  
Transformer TC-3  
Disconnect N-4  
Disconnect N-3  
Disconnect EM-2  
Disconnect EM-3  
Disconnect ES-1  
Buss-Riser EF-1 (Tap Can )

**Room EKG**

Panel 3NPG

**Room E342a-1 (Lab)**

Panel 3NPA

**Room A370 Q1**

Panel UL-3-3D Sect. #1  
Panel UL-3-3D Sect. #2  
Panel CUL-3-3D  
Panel CLL-3-3D  
Disconnect Transformer 25

Disconnect Transformer 69  
Transformer 25  
Transformer 69

**Room A371-1**

Panel 3EQHA  
Panel 3LCB  
Panel 3LCA  
Panel 3HLS  
Panel 3LLS  
Panel 3HC  
Transformer T-1  
Transformer T-2  
Disconnect 3LCB

**Room A311-1**

Panel CLL-2-3A Sect. #1  
Panel CLL-2-3A Sect. #2  
Panel UL-2-3A Sect. #1  
Panel UL-2-3A Sect. #2  
Disconnect Transformer 35  
Disconnect Transformer 34  
Transformer 34  
Transformer 35

**Electric Room A337B-1**

Panel UL-1-3B Sect. #1  
Panel UL-1-3B Sect. #2  
Panel LL-1-3B  
Panel LH-1-3B

**Room B390-1**

Panel CLH-1-3B  
Panel CUL-1-3B

**Room A351B-1**

Transformer T-10  
Disconnect Transformer 10

**Room E362-1(LAB)**

Panel 3NPD

**Room E307B-1(LAB)**

Panel 3NPE

**Room E316-1 & 318-1(LAB)**

Panel 3NPB

**Room A389-1**

Panel LEM.CR.3A

Panel LEM.CR.3B

Transformer EMCR-2

Transformer EMCR-2

**FOURTH FLOOR**

**Room E402-1**

Panel 4NPDB

Panel 4NPH

Panel 4NPG

Panel 4NPF

Transformer T-6

Disconnect N-13

**Room E475-1**

Panel UPS

Panel 4NPDA

Panel 4NPD

Panel 4NPC

Panel 4NPA

Panel 4NPB

Panel 4HLA

Panel 4CPA

Panel 4CPB

Disconnect N-5

Disconnect N-9

Disconnect EM-4

Disconnect E-449

Disconnect Liebert Unit

Disconnect UPS

Transformer TC-3

Transformer T-5

Disconnect IRM Strong

**Room E420-1(Library)**

Panel 4NPE

**Room EC-2-4A**

Panel UL-2-4A Sect. #1  
Panel UL-2-4A Sect. #2  
Panel LL-2-4A  
Panel CLH-2-4A  
Panel CUL-2-4A  
Panel ELH-2-4A  
Disconnect DH-2-B  
Disconnect T-37  
Disconnect CUL-SICU-5B  
Transformer 36  
Transformer37

**Room A497A-1**

Panel UL-I-4B Sect. #1  
Panel UL-I-4B Sect. #2  
Panel LL-I-4B  
Panel LH-I-4B

**Room EC-1A-4B**

Disconnect T-11  
Transformer T-11

**FIFTH FLOOR**

**Room E521-1**

Panel 5NPF

**Room 575-1(LAB)**

Panel 5NPE

**Room E570-1**

Panel 5NPDA  
Panel 5NPA  
Panel 5NPD  
Panel 5LSA  
Panel 5HLA  
Panel 5CHA

Panel 5CPA  
 Panel CPA Sub Panel A  
 Panel MB30300XXX3V41  
 Disconnect ES-12  
 Disconnect ES-13  
 Disconnect ES-14  
 Disconnect ES-15  
 Disconnect ES-16  
 Disconnect ES-17  
 Disconnect EM-5  
 Disconnect EM-6  
 Disconnect N-7  
 Disconnect N-8  
 Transformer T-7  
 Transformer TC-4

**Room E566-1**

Panel 5NPB

**Room E502-1**

Panel 5NPH  
 Panel 5NPDB  
 Panel 5NPG  
 Transformer T-9  
 Disconnect N-14

**Room A5070A-1**

Panel LL-3-5A  
 Panel UL-3-5A Sect. #1  
 Panel UL-2-5A Sect. #2  
 Panel CUL-3-5A  
 Transformer 28  
 Disconnect Transformer 28

**Room A512A-1**

Panel LL-2-5A  
 Panel UL-2-5A Sect. #1  
 Panel UL-2-5A Sect. #2  
 Disconnect Transformer 38  
 Disconnect RM#503  
 Transformer T-38

**Room E471**

Panel 4EOHA  
Panel 4EQPA

**Room A540B-1**

Panel LH-1-5B  
Panel LH-1-5B  
Panel UL-1-5B Sect. #1  
Panel UL-1-5B Sect. #2  
Disconnect Clean Linen  
Disconnect Soiled Linen  
Disconnect Dumb Water

**Room A542B-1**

Disconnect Transformer 12  
Transformer 12

**Room A531-1**

Panel CUL-SICU-5B-A  
Panel CUL-SICU-5B-B

**Fifth Floor Penthouse**

MCC-1  
Disconnect EF-3  
Disconnect EF-2  
Disconnect EF-1  
Panel UL-1-5B Sect. #1A  
Disconnect S1  
Disconnect S2  
Disconnect P6  
Disconnect P3  
Disconnect P4  
Disconnect P5

**E-Wing Penthouse**

MCC E1  
MCC N1  
Panel #1  
Panel PNPA  
Transformer T-9  
Transformer TE-2  
Transformer O/R Suites

Disconnect Fan Exhaust  
Disconnect AC-5E  
Disconnect IR Compressor  
Disconnect 1-EF-1E  
Disconnect #1 Comp. Control  
Disconnect #2 Comp. Control

**Air Compressor Room**

Disconnect Compressor #1  
Disconnect Compressor #2

**Elevator Room**

Disconnect P9  
Disconnect P10  
Disconnect P7  
Disconnect P8  
Disconnect EF-4  
Panel #1  
Disconnect New A/C Unit

**NURSING HOME**

**FIRST FLOOR**

**First Floor Engineering Space 140**

Panel K  
Panel LK  
LIK Disconnect  
TLIK Transformer  
TK Transformer

**Electrical Closet**

Panel LIN  
Panel I-L  
Panel LEI  
Disconnect Transformer LI  
Transformer LI

**Main Electrical Room**

MCC #1  
Main Switchgear  
MCC #2

Disconnect EL  
 ATS EL  
 ATS EQ  
 ATS EL-2

## **SECOND FLOOR**

### **Room 208-12**

Panel L2NA  
 Panel L-2N  
 Panel PE2  
 Panel 2LI  
 Panel LE-2  
 Disconnect PE-2 Transformer  
 Disconnect L2N Transformer  
 Transformer L2N  
 Transformer PE-2

### **Room 239-12**

Panel 2H  
 Panel 2L  
 Disconnect 2L Transformer  
 Transformer 2L

## **THRID FLOOR**

### **Room 308-12**

Panel L3NA  
 Panel L3N  
 Panel PE3  
 Panel 3LOI  
 Panel LE3  
 Disconnect Transformer L3N  
 Disconnect PE3  
 Transformer L3N  
 Transformer PE3  
 Panel #1  
 Disconnect Elevator #3  
 Disconnect CAR LTS #3  
 Disconnect Heater EH-3  
 Disconnect Elevator #2  
 Disconnect CAR LTS #2  
 Disconnect Elevator #1  
 Disconnect CAR LTS #1  
 Disconnect Heater EH-2  
 Panel EV-1

## **BUILDING 11**

### **Room 101**

Panel ACLA  
Panel ACPA

### **Roof**

MCC-1

### **Outside Building**

Disconnect 111AC4-1

### **Tunnel Area**

Panel S  
Panel S-1  
Panel N  
Panel N-1

### **Room 116**

Panel ACEB  
Panel MCB

## **MRI BUILDING**

### **Electrical Room 203**

Panel D-ELH  
Panel E-ECH  
Panel G-ECL  
Panel A-H  
Panel M-DP  
Disconnect Breaker 43  
Disconnect Fire Alarm Breaker  
Panel B-L  
Transformer A

## **HOSPITAL**

### **Hall 5<sup>th</sup> Floor Hemo Dialysis**

Panel 5A.CR2.PI  
Panel 5A.CR3.PI

### **5<sup>th</sup> Floor Electrical Room (New)**

Panel 5A.N.LA  
Panel 5A.CR3.LI  
Panel 5A.LS.LA  
Panel 5A.N.LI  
Panel 5A.CR3.LA  
Panel 5A.LS.LI

### **Room 526-1**

Panel 208/120  
Master Alarm Panel

### **3<sup>rd</sup> Floor Electrical Closet Across from Room A337B-1**

Panel 3A.N.DLI

### **3<sup>rd</sup> Floor New Electrical Room**

Panel 3B.CR2.DP2  
Panel 3B.N.DPA  
Panel 3B.N.DPI  
Panel 3B.CR3.DPI  
Panel 3B.LS.LI  
Panel CUL.I.3B  
Panel 3B.LS.DLA  
Panel 3B.CR3.DLA

### **2<sup>nd</sup> Floor Room 290-1**

AHU1E.SAF.VFD  
AHU2E.SAF.VFD  
AHU1E.HTWHL.SS  
AHU1E.EAF.VFD  
AHU1E.OAF.VFD  
AHU2E.HTWHL.SS  
AHU2E.EAF.VFD  
AHU2E.OAF.VFD

AHU-9E-VFD

E-Wing AHU3E.OAF 15HP/480V VFD

E-Wing AHU3E.EAF 15HP/480V VFD

## **BED TOWER**

### **6<sup>th</sup> Floor Electrical Room**

HPI-EQ-9 MA-1

HPI-EQ-8 MU-1

EFTB-3

EFTB-4

DP-P

Panel LP-1

HPI-EQ

Transformer TLPI-EQ

LPI-EQ

AHU-21

AHU-2

HRU-2

HRU-EF2

AHUI-1

HRU-1

EF-TB-2

EF-TB-1

RF-1

HRU-OAF-1

HRU-EF-1

HRU-OAF-2

AHU-2-2

RF-2

HRU-EF-3

HRU-OAF-3

AHU-3-2

I-P-1

I-P-2

RF-3

### **4<sup>th</sup> Floor Electrical Room**

Panel L42-CR

Panel L42-CRA

Panel L41-LS

Panel H42-CR

Panel H41-SQ

Panel H42

Panel L42

Panel L42-A  
Panel L42-B  
Panel TL-42

**4<sup>th</sup> Floor Electrical Room West**

Panel L43-CRA  
Panel L43-CR  
Panel H43-CR  
Panel H43  
Panel L43  
Panel L43-A  
Panel L43-B  
Panel TL-43-CR  
Panel TL-43

**4<sup>th</sup> Floor Electrical Room East**

Panel L41-CRA  
Panel L41-CR  
Panel TL41-CR  
Panel H41-CR  
Panel L41  
Panel L41-A  
Panel L41-B  
Panel H41  
Panel TL-41

**5<sup>th</sup> Floor Electrical Room**

Panel L52 A  
Panel L52  
Panel TL52  
Panel H52  
Panel H51-EQ  
Panel H51-LS  
Panel L51-LS  
Panel TL51-LS  
Panel H52-CR  
Panel L52-CR  
Panel TL52-CR

**5<sup>th</sup> Floor Electrical Room West**

Panel H53-CR  
Panel L53-CR  
Panel TL53-CR  
Panel H53

Panel TL53  
Panel L53  
Panel L53-A

**3<sup>rd</sup> Floor Electrical Room**

Panel L32-B  
Panel L32-A  
Panel L32  
Panel TL32  
Panel H32  
Panel H31-EQ  
Panel H31-LS  
Panel L31-LS  
Panel H32-CR  
Panel LC2-CRA  
Panel TL31-LS  
Panel TL32-CR

**3<sup>rd</sup> Floor Electrical Room West**

Panel H33  
Panel TL33  
Panel L33  
Panel L33A  
Panel L33B  
Panel L33-CRA  
Panel L33-CR  
Panel TL33-CR  
Panel H33-CR

**3<sup>rd</sup> Floor Electrical Room East**

Panel L31-CRA  
Panel L31-CR  
Panel TL31-CR  
Panel H31-CR  
Panel H31  
Panel L31  
Panel L31A  
Panel L31B  
Panel TL-31

**2<sup>nd</sup> Floor Electrical Room**

Panel L22B  
Panel L22A  
Panel L22

Panel DP2  
 Panel EQ-DP2  
 Panel L21-LS  
 Panel CR-DP3  
 Panel L22-CRA  
 Panel L22-CR  
 Panel TL21-EQ  
 Panel L21-EQ

**2<sup>nd</sup> Floor Electrical Room West**

Panel L23-CRA  
 Panel L23-CR  
 Panel TL23-CR  
 Panel CR-DP4  
 Panel DP-3  
 Panel TL-23  
 Panel L-23  
 Panel L-23A  
 Panel L-23B

**2<sup>nd</sup> Floor Electrical Room East**

Panel L21  
 Panel L21A  
 Panel L21B  
 Panel DP-1  
 Panel CR-DP-2  
 Panel TL21-CR  
 Panel L21-CR  
 Panel L21-CRA  
 Panel TL-21

**6<sup>th</sup> Floor Passenger Elevator Equipment Room**

Disconnect P11  
 Disconnect Lights P11  
 Disconnect P12  
 Disconnect Lights P12  
 Disconnect P13  
 Disconnect Lights P13

**6<sup>th</sup> Floor Service Elevator Equipment Room**

Disconnect S13  
 Disconnect Lights S13  
 Disconnect S14  
 Disconnect Lights S14

Disconnect S15  
Disconnect Lights S15

**1<sup>st</sup> Floor Electrical Room East**

Panel H12  
Panel L12-CR  
Panel L12-CRA  
Panel TL12-CR  
Panel TL12  
Panel L12  
Panel L12A  
Panel L12B

**Emergency Room Electrical Room**

Panel TL14  
Panel H14  
Panel L14  
Panel L14A  
Panel L14B  
Panel L14-CR  
Panel L14-CRA  
Panel H14-CR  
Panel TL14-CR

**Basement Electrical Room**

Panel HB-1  
Panel LB-1  
Panel TLB1  
Panel HB-1-EQ

**Main Electrical Room Bed Tower Emergency Room**

ATS-LS  
ATS-CR  
ATS-EQ  
Panel DP1-EQ  
Panel H11-EQ  
Panel TL11-EQ  
Panel L11-EQ  
Panel CR-DP1  
Panel H11-CR  
Panel L11-CR  
Panel L11-CRA  
Panel LS-DP1  
Panel TL-11-CR

Bed Tower Generator 1200 Amp Break  
Transformer TLUS-1  
Transformer TLUS-2  
Switchgear US-1  
Switchgear US-2

**Full Generator Power Building**

Panel GA  
Panel G1

**Nursing Home**

Critical Life ATS  
Essential Life ATS  
Generator Room 500 Amp Breaker