

APPENDIX 3: HINES & JOLIET SCHEDULE

October 1, 2017 THRU September 30, 2022

BLDG-200

PARAGRAPH 1... EXHAUST AIR FAN SYSTEM E-47 ALL FANS AND GRILLES.

October & April each FY

PARAGRAPH 2... EXHAUST SERVING THE BASEMENT MORGUE AND ALL AUTOPSY TABLE EXHAUST SYSTEMS.

February, May, August, November each FY

PARAGRAPH 3... EXHAUST AIR FAN SYSTEMS E-13, E-16, E-17, E-19, E-21, E-28, E-29, E-31, E-38 AND ALL FANS AND GRILLES.

February & August each FY

PARAGRAPH 4... EXHAUST AIR FAN SYSTEM E-15, SURGICAL SUITES AND ALL FANS AND GRILLES.

February, May, August, November each FY

PARAGRAPH 5... EXHAUST AIR FAN SYSTEMS E-8 THROUGH E-12 AND ALL FANS AND GRILLES.

November each FY

PARAGRAPH 6... EXHAUST AIR FAN SYSTEMS E-18, ROOM D108; E-20, ROOMS D108B AND D108C E-22; E-23, ROOM D122; E-24, ROOM D108A; E-2S, ROOM D108E; E-26 FLOOR

SECTIONS "C" AND "D" AND ROOM B109, C129, D110A AND D118B; E-28, ROOM D133 E-39, E-46, ROOM B109H; AND E-30 BASEMENT, 1st FLOOR AND SECOND FLOOR RETURN AIR; AND ALL FANS, GRILLES AND HOODS.

January & June each FY

PARAGRAPH 7... SUPPLY RETURN AND EXHAUST AIR AND ALL FANS, VENTS, GRILLES AND DIFFUSERS SERVING THE FOLLOWING AREAS:

- a. CARDIAC CATH, 1ST FLOOR, BLDG. 200.
- b. MEDICAL INTENSIVE CARE UNIT (MICU), 2A-200,

- c. SURGICAL INTENSIVE CARE UNIT (SICU) 2B-200.
- d. SPS A022A, A023C, A023D, A023F, A023H, A023I, A024A, A024B, A025, A025B, A025C (CART WASHER AREA), A025C (SOILED WORK AREA).
- e. BRONCHOSCOPY 13TH FLOOR 1349-7 & 1349-8.
- f. AMBULATORY SURGERY (A/C 100) & SURGICAL SUITES: A003, A004, A005, A006, A009, A010, A011, A012, A015, & A018.
- g. ACUTE SURGERY: "C" SECTION, 2ND FLOOR, BLDG. 200.
- h. DAY SURGERY: "D" SECTION, 2ND FLOOR, BLDG. 200.
- i. PACU/RECOVERY: "D" SECTION, 2ND FLOOR, BLDG. 200, INCLUDING EF-4 EXHAUST FAN AND DUCTWORK IN "D" DOGHOUSE, BLDG. 200.

February & August each FY

PARAGRAPH 8... SUPPLY AND EXHAUST AIR AND ALL FANS, GRILLES, VENTS AND DIFFUSERS SERVING THE CT SCAN AREA, ROOM C103; THE RADIOTHERAPY TREATMENT AREAS, ROOMS D007, D008, AND D010.

March each FY

PARAGRAPH 9... AHU CLEANING S-1, S-2, S-3, S-4, S-5, S-7, LOBBY, INPATIENT AND OUTPATIENT PHARMACY, GU, ENDOSCOPY, SPS, AND AHU's ON FLOORS 5,7,8,9,11, AND 12.

November each FY

PARAGRAPH 10... FAN COIL UNITS, FLOORS 1 THROUGH 14 AND ELEVATOR MECHANICAL ROOM IN PENTHOUSE BLDG. 200.

October & April each FY

PARAGRAPH 11... EXHAUST AIR FAN SYSTEM E-27 AND ALL FANS, GRILLES, CANOPY HOODS AND DISHWASHER HOODS BASEMENT MAIN KITCHEN AND PATIENT EDUCATION ROOMS.

January, May & September each FY

PARAGRAPH 12... SUPPLY AIR CEILING DIFFUSERS, BASEMENT MAIN KITCHEN AND PATIENT EDUCATION ROOMS.

January, May & September each FY

PARAGRAPH 13.... SOILED LINEN CHUTE SYSTEM, SUB-BASEMENT THROUGH 15th FLOOR.

June & December each FY

PARAGRAPH 14... SOILED LINEN CONVEYOR BELT SYSTEM FROM THE SUB-BASEMENT TO THE TOP OF THE SOILED LINEN COLLECTION ROOM ON THE EAST SIDE OF THE LOADING DOCK.

December & June each FY

PARAGRAPH 15... CLEAN 4 COOLING TOWERS IN BLDG. 200 BEFORE THE COOLING SEASON STARTS ONCE PER YEAR.

March each FY

PARAGRAPH 16... TWO CLEANINGS PER CONTRACT PERIOD OF THE COMPLETE SUPPLY AND EXHAUST BRANCH DUCT WORK SYSTEMS ON ALL FLOORS IN BLDG 200.

February & July each FY

PARAGRAPH 17... ONE REPLACEMENT OF PRE-FILTERS PER QUARTER, AND ONE REPLACEMENT ANNUALLY OF HEPA FILTERS ON EF-16A & EF-16B (LOCATED IN THE PENTHOUSE OF BLDG. 200), INCLUDING ASSOCIATED MICU (QTY2), SICU (QTY2), EXHAUST SYSTEMS ER A142-200, EF-4 (D-DOG HOUSE), AND EF-5 (MORGUE D018-200).

PRE-FILTERS

January, April, July, October each FY

HEPA FILTERS

October each FY

PARAGRAPH 18... ONE REPLACEMENT OF PRE-FILTERS PER QUARTER, ONE REPLACEMENT OF INTERMEDIATE FILTERS SEMI-ANNUALLY, AND ONE REPLACEMENT OF HEPA FILTERS ANNUALLY ON THE ACUTE SURGERY AHU (C-DOG HOUSE), DAY SURGERY (D-DOG HOUSE). THIS WORK TO BE PERFORMED AFTER NORMAL BUSINESS HOURS.

PRE-FILTERS

November, February, May, July each FY

INTERMEDIATE FILTERS

February, July each FY

HEPA FILTERS

July: each FY

PARAGRAPH 19...MONTHLY CLEANING OF ALL RANGE HOODS, FILTERS AND ASSOCIATED DUCT WORK LOCATED IN KITCHEN C032.

Monthly each FY

BLDG 217

PARAGRAPH 1... EXHAUST, RETURN AIR AND ALL FANS AND GRILLES, 1ST AND 2ND FLOORS

June & December: each FY

PARAGRAPH 2... EXHAUST AIR FAN SYSTEMS AND ALL GRILLES, RANGE HOODS AND DISHWASHER HOODS, SATELLITE KITCHEN AND PATIENT DINING ROOM

June & December: each FY

PARAGRAPH 3... SUPPLY AIR CEILING DIFFUSERS, SATELLITE KITCHEN AND PATIENT DINING ROOM.

June: each FY

PARAGRAPH 4... SUPPLY AIR AND ALL FANS AND DIFFUSERS, 1st AND 2nd FLOORS.

November: each FY

PARAGRAPH 5...COMPLETE SUPPLY AIR FAN SYSTEM INCLUDING ALL VERTICAL AND BRANCH DUCT WORK SYSTEMS AND FANS SUPPLYING AIR TO THE THREE ATRIUMS.

September: each FY

PARAGRAPH 6... MONTHLY CLEANINGS OF RANGE HOODS AND ALL ASSOCIATED DUCT WORK, FILTERS AND FANS LOCATED IN KITCHEN 217.

Monthly each FY

PARAGRAPH 7... ANNUAL CLEANING OF THE COMPLETE DRYER EXHAUST SYSTEMS.

September: each FY

BLDG 221

PARAGRAPH 1... SUPPLY RETURN, EXHAUST AIR FAN SYSTEMS AND ALL GRILLES, VENTS AND DIFFUSERS.

January & July each FY

PARAGRAPH 2... ANNUAL CLEANING OF THE COMPLETE DRYER EXHAUST SYSTEM.

September: each FY

PARAGRAPH 3... ANNUAL CLEANING OF ALL AIR SUPPLY, RETURN, EXHAUST GRILLES.

September: each FY

PARAGRAPH 4... QUARTERLY CLEANING OF RANGE HOODS AND ASSOC DUCTWORK.

November, February, May & August each FY

BLDG 228

PARAGRAPH 1...SUPPLY RETURN, EXHAUST AIR AND ALL FANS, GRILLES, VENTS AND DIFFUSERS, BASEMENT THROUGH 5TH FLOOR.

April: each FY

PARAGRAPH 2... CLEAN COMPLETE DUST COLLECTER SYSTEM.

Monthly each FY

PARAGRAPH 3... CLEAN COOLING TOWERS.

March: each FY

PARAGRAPH 4... CLEAN DRYER EXHAUST SYSTEM.

March: each FY

PARAGRAPH 5... WEEKLY CLEANING OF DUST COLLECTOR BARRELS.

Weekly each FY

BLDG 113

PARAGRAPH 1... DUST COLLECTOR SYSTEM.

Monthly each FY

PARAGRAPH 2... WEEKLY CLEANING OF DUST COLLECTOR BARRELS.

Weekly each FY

PARAGRAPH 3... TWO CLEANINGS DURING THE CONTRACT PERIOD OF ALL SUPPLY, RETURN, AND EXHAUST VENTS ON THE 1ST FLOOR.

January & July each FY

PARAGRAPH 4... TWO CLEANINGS DURING THE CONTRACT PERIOD OF ALL SUPPLY, RETURN, AND EXHAUST VENTS ON THE 2ND FLOOR.

February & August each FY

PARAGRAPH 5... DRYER EXHAUST SYSTEMS ONE CLEANING PER CALENDAR YEAR OF THE DRYER EXHAUST SYSTEM.

June: each FY

PARAGRAPH 6... TWO CLEANINGS PER CONTRACT PERIOD OF THE COMPLETE S-1 AHU.

June & September each FY

BLDG 128

PARAGRAPH 1... COMPLETE AHU'S AND COMPLETE SUPPLY, RETURN, AND EXHAUST INCLUDING MAIN TRUNKS GRILLES AND DIFFUSER.

April & October each FY

PARAGRAPH 2... DRYER EXHAUST SYSTEMS.

March: each FY

PARAGRAPH 3... ONE ANNUAL CLEANING OF EF-2, EF-3, EF-5, AND EF-6 (LOCATED ON THE ROOF OF BLDG 128).

July: each FY

BLDG-1

PARAGRAPH 1... AIR HANDLING UNITS AND COMPLETE SUPPLY AND EXHAUST AIR FAN SYSTEMS INCLUDING ALL VERTICAL AND BRANCH DUCT WORK SYSTEMS AND ALL FANS, GRILLES, VENTS AND DIFFUSERS SERVING THE FOLLOWING AREAS: B416-1 (1 SUPPLY AHU & 3 EXHAUST FANS, C436-1, C439-1, F225-1, F233-1, AND G235-1.

To be scheduled after the contract is awarded. To be performed each FY.

PARAGRAPH 2...SUPPLY, EXHAUST AND ALL FANS, GRILLES, VENTS AND DIFFUSERS SERVING THE FOLLOWING AREAS:

a. NUCLEAR MEDICINE PATIENT TREATMENT AND COMPUTER AREAS, ROOMS G201 AND G201B.

b. MICROBIOLOGY LABORATORIES, SECTION F-2 (F254-1).

c. P-2 CONTAINMENT AREA, SECTION A-4 (A403-1 EXHAUST AHU & A411-1 SUPPLY AHU).

July: each FY

PARAGRAPH 3... SUPPLY, EXHAUST AND ALL FANS, GRILLES, VENTS AND DIFFUSERS, VETERINARY MEDICAL UNIT, SECTIONS A-4, B-4 AND C-4 & F309-1.

February & August: each FY

PARAGRAPH 4.... CLEAN COOLING TOWER D108A-1.

March: each FY

PARAGRAPH 5...DRYER EXHAUST CLEANING, VMU, B451A-1.

March: each FY

BLDG 33

PARAGRAPH 1... (EAST & WEST) AIR HANDLING UNITS 1ST FLOOR, AND COMPLETE SUPPLY, RETURN AND EXHAUST FAN AIR SYSTEMS INCLUDING ALL BRANCH DUCT WORK SYSTEMS.

October: each FY

BLDG-45

PARAGRAPH 1.... SUPPLY, RETURN, EXHAUST AND ALL FANS, GRILLES, VENTS, DIFFUSERS, CANOPY HOODS AND DISHWASHER HOODS SERVING THE CANTEEN FOOD COURT KITCHENS, FOOD PREPARATION AND SERVING AREAS, DINING ROOM AND VENDING MACHINE AREA.

May: each FY

PARAGRAPH 2...MONTHLY CLEANING OF ALL RANGE HOODS, FILTERS AND ASSOCIATED DUCT WORK LOCATED IN KITCHEN.

Monthly: each FY

BLDG 48

PARAGRAPH 1...AIR HANDLING UNITS 1ST & 2ND FLOOR, AND COMPLETE SUPPLY, RETURN AND EXHAUST FAN AIR SYSTEMS INCLUDING ALL BRANCH DUCT WORK SYSTEMS 1ST & 2ND FLOOR.

October & April: each FY

BLDG 229

PARAGRAPH 1...AIR HANDLING UNITS 1ST FLOOR, AND COMPLETE SUPPLY, RETURN AND EXHAUST FAN AIR SYSTEMS (2 EXHAUST FANS), INCLUDING ALL VERTICAL AND BRANCH DUCT WORK SYSTEMS ON 1ST FLOOR.

February & August: each FY

BLDG 220

PARAGRAPH 1... CLEAN COOLING TOWER IN BLDG. 220.

March: each FY

PARAGRAPH 2...AIR HANDLING UNITS 1ST & 2ND FLOOR, AND COMPLETE SUPPLY, RETURN AND EXHAUST FAN AIR SYSTEMS INCLUDING ALL BRANCH DUCT WORK SYSTEMS 1ST & 2ND FLOOR.

January, May & September: each FY

BLDG 100

PARAGRAPH 1...AIR HANDLING UNITS 1ST FLOOR, AND COMPLETE SUPPLY, RETURN AND EXHAUST FAN AIR SYSTEMS INCLUDING ALL VERTICAL AND BRANCH DUCT WORK SYSTEMS, VENTS, DIFFUSERS, AND GRILLES, 1st & 2nd FLOOR.

March & September: each FY

PARAGRAPH 2... DRYER EXHAUST SYSTEM CLEANING.

September: each FY

JOLIET CBOC

PARAGRAPH 1...AIR HANDLING UNITS 1ST FLOOR, AND COMPLETE SUPPLY, RETURN AND EXHAUST FAN AIR SYSTEMS INCLUDING ALL BRANCH DUCT WORK SYSTEMS, VENTS, DIFFUSERS, AND GRILLES, 1st & 2nd FLOOR.

April & October: each FY