

# LINE ITEM IV

Site	Closest	Status/or Requirements
JLM	1A115	1;2;4;5
JLM	1B139	1;2;4;5
JLM	1B155	1;2;4;5
JLM	1C144	1;2;4;5
JLM	1C160	1;2;4;5
JLM	1D141	1;2;4;5
JLM	1D175	1;2;4;5
JLM	1E111	1;2;4;5
JLM	1E164	1;2;4;5
JLM	1E213	1;2;4;5
JLM	2A114	1;2;4;5
JLM	2B138	1;2;4;5
JLM	2B169	1;2;4;5
JLM	2C105	1;2;4;5
JLM	2C160	1;2;4;5
JLM	2D111	1;2;4;5
JLM	2D164	1;2;4;5
JLM	2E100	1;2;4;5
JLM	2E154	1;2;4;5
JLM	4A111	1;2;4;5
JLM	4B140	1;2;4;5
JLM	4C123	1;2;4;5
JLM	4D140	1;2;4;5
JLM	4E123	1;2;4;5
JLM	5A112	1;2;4;5
JLM	5B138	1;2;4;5
JLM	5C140	1;2;4;5
JLM	5D150	1;2;4;5
JLM	5E123	1;2;4;5

## LEGEND

1. SAS(Security Access System)
2. Hard Ceiling
3. Secure hinges
4. Door Sweep
5. Equipment Rack
6. Relocate
7. install expanded metal over glass window

JLM	6A110	1,2,4,5
JLM	6B135	1,2,4,5
JLM	6C123	1,2,4,5
JLM	6D140	1,2,4,5
JLM	6E123	1,2,4,5
JLM	7A114	1,2,4,5
JLM	7B139	1,2,4,5
JLM	7C123	1,2,4,5
JLM	7D130	1,2,4,5
JLM	7E115	1,2,4,5
JLM	7E122	1,2,4,5
JLM	GA106	1,2,4,5
JLM	GB107	1,2,4,5
JLM	GB132	1,2,4,5
JLM	GC140	1,2,4,5
JLM	GC197	
JLM	GC197	Secure
JLM	GD101	1
JLM	GD111	1,2,4,5
JLM	GD126	1,2,4,5
TOTAL		
JLM	GF138	Secure
JLM	Penthouse	1
LR	Vet Drop-In Aux	
LR	Vet Drop-In Center	Relocating to Downtc

Status/ or Requirements  
1,4,5; Remove or secure indoor luvre

Site	SIDE	Bldg	Clset / Room	Secure
NLR		1	207	Secure
NLR		2	Ground	???
NLR		3	Ground	7;1
NLR		5	104	Secure

NLR	6	Fire Dept. Office	1;9	
NLR	7	Ground	1;2;4;5	
NLR	11	Ground	1	
NLR	16	InBrk Rm/IDF	Run power to above rack; 1;9	
NLR	26	Ground	1;9	
NLR	32	Bsmnt	1;9	
NLR	33	16G Brk Rm	1	
NLR	34	B34 Wm Rstrm 108 ?		
NLR	37	109	1	
NLR	40	Bsmnt		
NLR	41	Bsmnt	1;2;4;5	
NLR	58	110	1;2;4;5	
NLR	58	133	1;2;4;5	
NLR	58	244A		
NLR	58	307		Secure
NLR	58	30	1; Security lighting over vault door	
NLR	58	30	1	
NLR	65	105, 103, 202	1;2;4;5	
NLR	66	ATTIC	Move switch up/sec/w piano hinges	
NLR	68	22	1;2;4;5	
NLR	69	Office Wall	8;7	
NLR	76	104		
NLR	80	G Mn Rstrm	1	
NLR	89	212	1	
NLR	89	212		
NLR	101	101	1	
NLR	102	132	1	
NLR	103	G	2;4;5	
NLR	104	212	1 Two doors	
NLR	106	Hall Clst near Conf	1;5	
NLR	111	3	8;7 bld closet other side of wall	

NLR	111	137A	8;7
NLR	115	Supv Ofc	1; 4;5
NLR	159	2	1; 4;5
NLR	170	GA104	
NLR	170	GB112	4;5
NLR	170	GE109	1; 4;5
NLR	170	GE111	1; 4;5
NLR	170	GH113	Secure
NLR	170	GK101	1;5
NLR	170	GK107 (Core)	1;5
NLR	170	1B125	1;5
NLR	170	1C125	1;5
NLR	170	1D125	
NLR	170	1E125	1;5
			1;5
NLR	170	1F116	1;5
NLR	170	1H121	1;5
NLR	170	1J121	1;5
NLR	170	1K121	1;4;5
NLR	170	1L119	1;5
NLR	170	1M119	1;5
NLR	170	2B119	1;5
NLR	170	2C117	1;5
NLR	170	2D119	1;4;5
NLR	170	2E119	1;5
NLR	170	2F122	1;5
NLR	170	2H121	1;5
NLR	170	2J121	1;5
NLR	170	2K121	1;4;5
NLR	170	2L117	1;5
NLR	170	2M119	1;5
NLR	170	3B119	1;5
NLR	170	3C119	1;5

NLR	S	170	3D119	1:4,5
NLR	S	170	3E119	1:5
NLR	N	170	3F122	1:5
NLR	N	170	3H119	1:5
NLR	N	170	3J121	1:5
NLR	N	170	3K121	1:4,5
NLR	N	170	3L119	1:9
NLR		170	3M120	Inclose Switch
NLR		182	Bsmnt	1:4,5 Two doors
NLR		185	Upstairs Brk Rm	1:9
NLR		190	212	
NLR		191	Firing Range	





TOTAL