NOTES:

1. ALL ROOMS WITH EXHAUST GRILLES SHALL HAVE DOORS WITH 1/2" UNDERCUTS.
2. REFER TO ENLARGED PLAN ON DRAWING MH601 FOR MECHANICAL ROOM DETAILS.
3. SIZES AND LOCATIONS OF DUCTWORK AND EQUIPMENT SHOWN ARE APPROXIMATE AND FOR DIAGRAMMATIC PURPOSES ONLY. FINAL SIZES AND LOCATIONS TBD.
4. CONTRACTOR SHALL FIELD COORDINATE DUCTS AND DIFFUSERS WITH ALL CEILING MOUNTED EQUIPMENT AND PATIENT LIFT SUPPORT SYSTEM.
5. MOISTURE RESISTANT CEILING HEATERS TO BE PROVIDED AND INSTALLED BY ELECTRICAL CONTRACTOR IN BARIATRIC TOILET/SHOWER ROOMS B104 AND B144. REFER TO DRAWING EL-201 FOR LOCATIONS.

1 SECOND FLOOR PLAN
1/8" = 1'-0"

KEY PLAN
NTS

SCALE: 1/8" = 1'-0"

Revisions	Date
Addendum 1	6/21/12
100% Submission	7/02/10
90% Submission	5/27/10
60% Submission	4/22/10

VA WESTERN NEW YORK HEALTHCARE SYSTEM
3495 BAILEY AVENUE
BUFFALO, NEW YORK 14215

Architect: URS — BUFFALO, NY., 77 GOODELL ST 716-856-5636

stamp

CARDIOLOGY	DATE	ENGINEERING MANAGER	DATE
INFECTION CONTROL	DATE	CARELINE MANAGER	DATE
SAFETY OFFICER	DATE	CHIEF OF STAFF	DATE

Drawing Title: SECOND FLOOR ("WARD B") MECHANICAL DUCTWORK PLAN

MEDICAL CENTER DIRECTOR DATE

ASSOCIATE MEDICAL CENTER DIRECTOR DATE

Project Title: RENOVATION OF BLDG #1, 2ND FLOOR, B-WARD

Building Number: 1 | Checked | Drawn

Location: V.A.M.C. BATAVIA, NEW YORK

Date: JULY 2, 2010 (UPDATED 10/07/10)

Station No.: 528

09-352 MH-202

Office of Facilities — Department of Veterans Affairs