

## NTS

DESIGNERS NOTES:  
1.PROVIDE A MOTORIZED DAMPER, IF APPLICABLE

2. PROVIDE DIRECT DRIVE FANS FOR LOCATIONS NOT EASILY ACCESSIBLE AND LESS THAN 2 HP.
3. MINIMUM CURB HEIGHT SHALL BE 12 INCHES [300 mm]. INCREASE HEIGHT, IF REQUIRED, TO OVERCOME SNOW DRIFT.



NTS




NTS



NTS



NTS



6 NTS

VA WESTERN NEW YORK HEALTHCARE SYSTEM  
3495 BAILEY AVENUE  
BUFFALO, NEW YORK 14215

**URS** BUFFALO, NY.,  
77 GOODELL ST.  
716-856-5636

Architec

stamp

MECHANICAL DETAILS  
(SHEET 8 OF 8)


Project Title	RENOVATION OF BLDG #1, 2ND FLOOR, B-WARD
---------------	---

Date  
JULY 2, 2010 (UPDATED 10/07/10)

Station No.

[illegible]

09-352 MH-609



Department of