


- GENERAL NOTES (THIS DWG)

- ⑪ RECESSED OUTLET BOX FOR HANDED GUARD SWITCH MOUNTED AT 4'-0" ABOVE FINISHED GRADE IN BOLLARD. EXTEND 3/4" CONDUIT FROM OUTLET BOX TO TELECOMMUNICATION ROOM AIRH.
- ⑫ RECESSED OUTLET BOX FOR ACCESS CONTROL SYSTEM MOUNTED AT 4'-0" AFT. EXTEND 3/4" CONDUIT FROM OUTLET BOX TO TELECOMMUNICATION ROOM AIRH.
- ⑬ PROVIDE A CEILING MOUNTED JUNCTION BOX FOR A MOTION INTRUSION DETECTOR. AN INTRUSION DETECTION ALARM SYSTEM WHICH DETECTS ENTRY INTO THE ROOM AND WHICH BROADCASTS A LOCAL ALARM (80 db TO 90 db) TO CAUSE AN ILLEGAL ENTRANT TO ABANDON A BURGLARY ATTEMPT.

1. PROVIDE CONNECTIONS BETWEEN FIRE ALARM SYSTEM AND ALL SPRINKLER SYSTEM FLAM, PRESSURE, AND SUPERVISORY SWITCHES, ETC. COORDINATE WITH THE SPRINKLER CONTRACTOR CONNECTIONS WITH THE SPRINKLER PLANS TO BE PROVIDED BY THE SPRINKLER CONTRACTOR.
2. PROVIDE TO HVAC ELECTRICAL SEQUENCE CONTROL WIRING PROGRAM FOR ALL HVAC EQUIPMENT TO MEET REQUIREMENTS TO ALL HVAC EQUIPMENT. NOTE: SOME HVAC CONNECTION MAY NOT BE SHOWN ON THIS DRAWING.
3. ALL WALL MOUNTED RECEPTACLES SHALL BE WIRING INDICATED ON DWG. 505 ELECTRICAL SYMBOL LEGEND AT 2'-0" AFF TO CENTER OF RECEPTACLE AND RECEPTACLES LOCATED UNDER WINDOWS SHALL BE 1'-0" AFF TO CENTER OF RECEPTACLE WHERE BOTTOM OF FINISHED WINDOW IS LESS THAN 2'-0" AFF. WHERE BOTTOM OF WINDOW IS MORE THAN 2'-0" AFF, RECEPTACLES AT 8" AFF TO CENTER OF RECEPTACLE. PROVIDE TO ARCHITECTURE DWG. 505 WINDOW TYPES AND SCHEDULE TO DETERMINE MOUNTING HEIGHTS.
4. REFER TO ELECTRICAL DRAWINGS AND DIVISION 26, 36, 37 & 28 SPECIFICATIONS FOR BACK BOXES, MOUNTING PLAYS, MOUNTING HEIGHTS, AND INSTALL FOR EACH LOW VOLTAGE SYSTEM (SECURITY SYSTEM, NURSE CALL SYSTEM, HAND SIGNAL SYSTEM, ETC.) PROVIDE INTERFACE BETWEEN FIRE ALARM SYSTEM IT LOW VOLTAGE SYSTEM 16 AND ANY SYSTEM IT LOW VOLTAGE SYSTEM 16 ARE REQUIRED.

CONSULTANTS:

S F C S | Architecture
Engineering
Planning
Interiors

SFCS Inc. ■ 305 South Jefferson Street
Roanoke, Virginia 24011.2003
540.344.6664 ■ Fax 540.343.6925
www.sfcs.com



ANDERSON & ASSOCIATES, INC.
Professional Design Services
www.andassoc.com

Approved: Project Director

[illegible]

Drawn	WAM
-------	-----

E2.2
Dwg 75 of

 Department of
Veterans Affairs