

**SECTION 02 83 33.13A
LEAD-BASED PAINT REMOVAL AND DISPOSAL**

XRF LEAD-BASED PAINT ASSESSMENT SUMMARY

**Chequamegon Bay Engineering
VA Milwaukee
Building 112 - Replace Emergency Generator
West Milwaukee, Wisconsin
Project #13204**

Sample Number	Functional Area / Room	Location in Room	Substrate	Color of Paint	Lead Content (mg/cm ²)	LBP Yes/No
Calibration	NA	NA	Standard	Calibration	1.0	NA
Calibration	NA	NA	Standard	Calibration	1.0	NA
01	Room 1 - Wall	Northeast	Concrete Block	Cream	0.05	No
02	Room 1 - Wall	South Center	Metal	Gray	0.14	No
03	Room 1 - Floor	East Center	Concrete	Gray	0.01	No
04	Room 1 - Wall	North Center	Concrete Block	Red	0.04	No
05	Room 1 - Door	Northeast	Metal	Cream	0.03	No
06	Room 1 - Generator	Center	Metal	Yellow	6.60	Yes

Notes:

1. Samples were analyzed on March 30, 2012.
2. Lead analysis conducted using a Niton X-Ray Fluorescence instrument.
3. Components that have > 0.7 mg/cm² lead are considered Lead-Based Paint in the State of Wisconsin. These materials may be regulated by the WDNR waste disposal regulations. Activities which disturb components determined to contain lead are regulated by OSHA.
4. NA = Not Applicable