


















SYMBOL KEY	
	SMOKE PARTITION
	GLASS/SPRINKLER 2-HOUR ASSEMBLY (DOUBLE LINE)
	GLASS/SPRINKLER 1-HOUR ASSEMBLY (SINGLE LINE)
	1-HOUR RATED WALL
	2-HOUR RATED WALL
	3-HOUR RATED WALL
	4-HOUR RATED WALL
	1-HOUR SMOKE BARRIER
	2-HOUR SMOKE BARRIER
	MAXIMUM PERMITTED TRAVEL DISTANCE
	FIRE EXTINGUISHER (2A-10BC)
	STANDPIPE HOSE OUTLET
	HORIZONTAL EXIT
	EXIT FLOW AND CAPACITY
	SUITE (LETTER INDICATES SUITE DESIGNATION)
	SMOKE RESISTANT CORRIDOR ≥ 6 FEET
	SMOKE RESISTANT CORRIDOR < 6 FEET

NOTE 1: DETAILED OCCUPANT LOAD AND EXIT CAPACITY CALCULATIONS ARE PROVIDED IN THE FIRE PROTECTION AND LIFE SAFETY ANALYSIS.


NOTE 2: FURTHER DESCRIPTION REGARDING THE BUILDING CLASSIFICATIONS, CONSTRUCTION TYPES AND FIRE RESISTANCE RATED/SMOKE BARRIER WALLS IS INCLUDED IN THE NARRATIVE AND THE FIRE PROTECTION AND LIFE SAFETY ANALYSIS.




SUITE BOUNDARY	
SUITE	AREA (SQ. FT.)
a	877
b	4,606
c	1,788
d	8,021
e	2,327
f	6,297
g	4,046
h	3,229
i	1,841
j	4,311
k	4,611
l	950
m	1,260
n	1,732
o	1,196
p	7,350
q	2,397
r	4,335
s	4,182
t	11,541
u	2,098
v	1,229
w	13,000

- CONCOURSE UTILITY LEVEL 4I NOTES:
1. THIS LEVEL FUNCTIONS AS A UTILITY ZONE, PROVIDING MECHANICAL SERVICES FROM THE CEP BLDG (#7) TO BLDGS #1 (BEDS), #2 (DIAGNOSTICS), #3 (OUTPATIENT), AND #6 (TRANSITIONAL LIVING).
 2. THIS LEVEL IS A SECURED ZONE WITH ACCESS ONLY BY MAINTENANCE STAFF.
 3. LEVEL 4I CONCOURSE IS NON-SPRINKLERED (PART OF A FULLY SPRINKLERED BUILDING).
 4. THE SPACE CONSISTS OF FLOOR TO CEILING UTILITY RACKS ON EACH SIDE OF A 6'-0" CLEAR PEDESTRIAN AISLE IN THE MIDDLE.

THIS IS A REPRESENTATION OF THE DESIGN CONCEPT.

IT SHOULD NOT BE CONSIDERED A DEFINITIVE PLAN FOR THE EXACT LOCATION OF THE PROTECTION FEATURES REPRESENTED. SEE THE APPROPRIATE PLANS FOR THE SPECIFIC DISCIPLINE FOR THE EXACT LOCATIONS.



		CONSULTANTS: DESMAN ASSOCIATES / PARKING CODE CONSULTANTS, INC. / CODE CONSULTANT THE SEXTANT GROUP / AV & ACOUSTICAL HAMMER DESIGN ASSOCIATES / FOOD SERVICE PYBURN & ODOM / ABATEMENT TATA & HOWARD / TANK CONSULTANT I.S.C. GROUP, INC. / IRRIGATION DAN EUSER WATER ARCHITECTURE, INC. / WATER FEATURE				ARCHITECT/ENGINEERS: studio NOVA SCHRENK & PETERSON CONSULTING ENGINEERS / CIVIL KORDA/NEMETH ENGINEERING / STRUCTURAL BR+A CONSULTING ENGINEERS / MECH. ELECT, PLUMBING, LOW VOLTAGE ARCHITECTURAL ENGINEERING / PLUMBING SCALES ASSOCIATES / FIRE PROTECTION		DRAWING TITLE CONCOURSE: UTILITY LEVEL LIFE SAFETY PLAN		PROJECT TITLE SLVHCS REPLACEMENT MEDICAL CENTER PROJECT		PROJECT NUMBER 629-HS2-401		BUILDING NUMBER		OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT  Department of Veterans Affairs	
REVISIONS:		DATE		APPROVED: PROJECT DIRECTOR 		LOCATION NEW ORLEANS, LOUISIANA		DATE February 29, 2012		CHECKED NF		DRAWN PMB/MS		DRAWING NUMBER 0AS110			