



DRAWING NOTES:

1. CONNECT TO INTEGRAL DISCONNECT SWITCH PROVIDED WITH FAN COIL UNIT (FCU TYPE AS INDICATED). PROVIDE CORE DRILLING AS REQUIRED TO RUN CONDUIT WITHIN PIPE CHASE BELOW (REUSE EXISTING CORE DRILLS WHERE POSSIBLE). SOME UNITS MAY NOT BE SHOWN, COORDINATE EXACT QUANTITY WITH MECHANICAL CONTRACTOR. REFER TO SCHEDULE ON DRAWING 69-E1 FOR FOU LOAD INFORMATION.
2. PANEL '69L' REFER TO SCHEDULE ON DRAWING 69-E1.
3. CONNECT TO INTEGRAL DISCONNECT SWITCH CEILING MOUNTED HEATING & VENTILATION UNIT (3 HP, 480V, 3 PH). EXTEND 3 #12, 1 #12 GIN IN EXISTING CONDUIT BACK TO PANEL '69K' IN BASEMENT & CONNECT TO EXISTING 20A, 3P CIRCUIT BREAKER SERVING HAZY UNIT THAT WAS REMOVED.
4. RUN TO CEILING SPACE WITHIN ARCHITECTURAL CHASE BEING CREATED TO CONCEAL PIPING & CONDUIT.
5. CONNECT TO INTEGRAL DISCONNECT SWITCH PROVIDED WITH CEILING MOUNTED FAN COIL UNIT (FCU TYPE AS INDICATED). REFER TO SCHEDULE ON DRAWING 69-E1 FOR FOU LOAD INFORMATION.

GENERAL NOTES:

1. REFER TO DRAWING '69-E1' FOR ELECTRICAL LEGEND, ABBREVIATIONS AND GENERAL NOTES.
2. FACEWAY INDICATED DASHED ON THIS DRAWING SHALL BE RUN IN PIPE TUNNEL OR MECHANICAL ROOM ON BASEMENT LEVEL OF BUILDING.

1 MAIN FLOOR PLAN - POWER - NEW WORK
SCALE: 1/8" = 1'-0"



ROOM NAME LIST

100	P.M.R.	114	GLASS ROOM	124	OCCUPATIONAL THERAPY
101	COMPUTER ROOM	115	ELECTRICAL ROOM	125	STORAGE
102	P.M.R. PHYSIATRIST	115A	OCCUPATIONAL THERAPY	126	AUDIOLOGY CLINIC
103	P.M.R. F.M.G. ROOM	116	GRAPHIC ARTS	125A	RECP ROOM
104	P.M.R. PHYSIATRIST	116A	OFFICE/LAB	125B	AUDIOLOGY CLINIC
106	F.S. LOCKERS	116C	BATH	125C	AUDIOLOGY CLINIC
106A	F.S. TOILET	117	JAN. CL.	125D	AUDIOLOGY CLINIC
107	MUN. ROOM	118	M.P. TOILET	128	STORAGE
107A	M.S. TOILET	119	SPEECH PATHOLOGY	128	STORAGE
108	CORRECTIVE THERAPY	120	STORE	129A	FLOWER STORAGE
108A	STORE	120A	R.M. CONFERENCE ROOM	130	VOLUNTARY COUNSELING
108B	THERAPY OFFICE	121	P.M.R. CONFERENCE ROOM	133	TOILET
109	PAINTS WORK SCREEN CLINIC	122	STORAGE	134	TOILET
109A	PAINTS WORK SCREEN CLINIC	122A	STORAGE	C-1	CORRIDOR
109B	SHOWER	122B	LOCKSMITH	C-2	CORRIDOR
111	JAN. CL.	122C	BREAK ROOM		
112	OFFICE	122D	FACILITIES FOREMAN OFFICE		
112A	STORE				
113	PHYSICAL THERAPY				

Revisions

Date

Consistors



DERBY ENTERPRISES
ARCHITECTURE
ENGINEERING
1301 ENTERPRISE COURT, SUITE 103-C
BEL AIR, MARYLAND 21014-1847
410.831.0078
410.838.1603



bkm
Engineering Life Spaces
Burdette Koehler Murphy & Associates, Inc.
Mechanical/Electrical Consulting Engineers
1423 Oakview Road
Suite 200
Baltimore, Maryland 21209
P: 410.577.2843
F: 410.577.2843
www.bkm.com

Drawing Title
**MAIN FLOOR PLAN
POWER - NEW WORK**

Approved: Facilities Engineering Service Chief
Approved: Medical Center Director

Project Title
**BUILDING 69
HVAC UPGRADE**

Building Number
69

Location
COATESVILLE, PENNSYLVANIA

Checked
ISP/RAK

Drawn
MB

Date
MARCH 14, 2012

Project No.
542-09-102

DRAWING NO.
69-ES

Rev. 22 of 22



DEPARTMENT OF
VETERANS AFFAIRS