

Replace surveillance Systems Questions and Answers

1) is the contractor responsible for purchase of HSPD-12 PIV cards, if so how many? Should a line item be included on the bid form for these cards? The cards are a significant cost of 1200 need to be provided for each employee that is added to the new database.

The intent is for the contractor to program the credential on the existing PIV cards that all VA employees have.

2) can the existing locking hardware on the doors to receive new card readers be re-used or are new locksets required, if so what brand of hardware is desired? What is the existing locking hardware on the 2 new card reader locations?

Existing door hardware shall remain, door strikes shall be replaced. Note: there are 12 new card readers per schedule on 00TY502.

3) are the existing card readers standalone or tied into any existing access control system? If so what is this system ?

Existing access control system is stand alone and shall be demoed as called for on the plans.