



- SPECIAL NOTES: (APPLY TO THIS DRAWING ONLY)
- 1 2-1/2" FDV AT FLOOR LANDING. LOCATE VALVE 60" A.F.F.
 - 2 2-1/2" FDV IN CABINET AT FLOOR LANDING. LOCATE VALVE 60" A.F.F.
 - 3 TO EXPANSION TANK. SEE H-SERIES DMG.
 - 4 3" UP TO 3" RD.
 - 5 AIR COMPRESSOR FOR LABORATORY AIR SYSTEM - DUPLEX.
 - 6 AIR COMPRESSOR FOR LABORATORY AIR SYSTEM - TRIPLEX.
 - 7 AIR RECEIVER, 30" DIA. X 60" HIGH.
 - 8 REFRIGERATED AIR DRYER.
 - 9 3/4" DOS UP TO DAY TANK.
 - 10 1-1/2" DOR UP TO DAY TANK.
 - 11 1-1/2" DN TO EACH COMPRESSOR.
 - 12 2-1/2" DN TO EACH COMPRESSOR.
 - 13 3/4" DOS AND DOR UP TO GENERATOR.
 - 14 CONTROL AIR DRYER. SEE H-SERIES DMG.
 - 15 CONTROL AIR RECEIVER. SEE H-SERIES DMG.
 - 16 DOMESTIC HOT WATER METER.
 - 17 VACUUM PUMPS.
 - 18 VACUUM TANK, 42" DIA. X 96" HIGH.
 - 19 HVAC EQUIPMENT. SEE H-SERIES DRAWINGS.
 - 20 LAB VACUUM PUMPS

8-0-1-1193

RECORD DRAWING
CORRECTED ON BASIS OF DATA
FURNISHED BY THE RESIDENT ENGINEER

RTKL / CSD / HENRY ADAMS (LV)
ARCHITECTS AND ENGINEERS
VILLAS OF CROSS KEYS
BALTIMORE, MARYLAND 21210

7th FLOOR PLAN
AREA A
PLUMBING

324 - BED
REPLACEMENT
HOSPITAL - PHASE II

Date 9/1/88
Project No. 511-001D
Drawing No. I-P34
Days 35 of 74

Approved Project Director
J. J. Miller

Scale 1/8" = 1'-0"
Checked

Location
VAMC - BALTIMORE, MD.

HA JOB NO. Y002240

AS BUILT
Revisions
6/17/94
Date

6/17/94
Date