

**REQUEST FOR INFORMATION (RFI)**  
**36C250-18-B-0081**

PROJECT NUMBER:	610-15-100	<b>Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.</b>
PROJECT TITLE:	Demolish Bldgs. 7,10,11,18,24,60 and Connecting Corridors	
PROJECT LOCATION:	Department of Veterans Affairs VA Northern Indiana HCS 1700 E. 38 <sup>th</sup> Street Marion, IN 46953	

SUBMITTED BY:	Shambaugh & Son, L.P.	CITY/STATE:	Marion, IN
PHONE:	260-224-5007		

**TO:**

Felecia Beamen, Contracting Officer  
Department of Veterans Affairs  
Network 10 Contracting Office  
8888 Keystone Crossing, Suite 1100  
Indianapolis, IN 46240  
[Felecia.Beamen@va.gov](mailto:Felecia.Beamen@va.gov)

RFI NO.: #E4	DATE:	SPEC/DWG. REFERENCE(s):  ED-101 – Coded Note #25
REPLY NEEDED BY: 1-2-2018		

**INFORMATION NEEDED:**

**Note says to provide live 120V for air monitors. Is the existing site lighting circuit live with photocells at each light?**

**REPLY:**

**RFI's will be answered by amendment(s) posted to fbo.gov.**

Yes, 120V is available at all site lighting.

REPLY FROM: HDR Inc.	DATE: 12-21-17
ATTACHMENTS: None.	COPY TO: