

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.		1. CONTRACT ID CODE		PAGE 1		OF PAGES 2		
2. AMENDMENT/MODIFICATION NUMBER 00002			3. EFFECTIVE DATE 01-04-2018		4. REQUISITION/PURCHASE REQ. NUMBER			5. PROJECT NUMBER (if applicable) None		
6. ISSUED BY Department of Veterans Affairs Network Contracting Office 22 4811 Airport Plaza Drive Suite 600 Long Beach CA 90815			CODE 00262		7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network Contracting Office 22 4811 Airport Plaza Drive Suite 600 Long Beach CA 90815			CODE 00262		
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders					(X)	9A. AMENDMENT OF SOLICITATION NUMBER 36C26218Q0210				
						9B. DATED (SEE ITEM 11) X 01-04-2018				
						10A. MODIFICATION OF CONTRACT/ORDER NUMBER				
						10B. DATED (SEE ITEM 13)				
CODE			FACILITY CODE							
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS										
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.										
12. ACCOUNTING AND APPROPRIATION DATA (If required)										
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.										
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.									
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).									
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:									
	D. OTHER (Specify type of modification and authority)									
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.										
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) This amendment is hereby issued to provide answers to the questions. Please see questions and answers!										
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.										
15A. NAME AND TITLE OF SIGNER (Type or print)					16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)					
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)			15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)			16C. DATE SIGNED		

- Is the requirement for a USP 797 Compounding Pharmacy or a USP 800 Compounding Pharmacy for Sterile Hazardous Drugs?
The requirement is for a USP 800 Compounding Pharmacy for Sterile Hazardous Drugs.
- Should the monthly rental fee include the cost of the Clean Room, equipment, HVAC system, pressurization system, and associated connections such HVAC ductwork?
Yes!
- Will the VA provide access to hot and cold water and a drain?
Yes!
- Is the Clean Room required to be self-contained?
No!
- Is the contractor / vendor required to provide the initial certification of the Clean Room?
Yes!
- Is the contractor / vendor required to provide the initial and on-going every six (6) months wipe down testing to verify contamination?
Yes!
- Is the Clean Room required to meet OSHPD requirements for a USP 800 Sterile Hazardous Compounding Pharmacy?
Yes!
- Is the contractor / vendor responsible for OSHPD approval?
No!
- How many moves of the Clean Room should be assumed for the pricing?
One removal at the end of the rental period. However, the modular clean room must be adaptable to allow for further expansion if needed.
- What is required for the “audit / validation” quarterly as identified in section III. E Scope, Tasks, or Requirements?

The requirement is for the followings:

- ISO environment certification for ante room and buffer room every 6 months to USP800 requirements (ISO Class, particle counts, air flow exchanges, etc.)
- Certification and testing of primary and secondary engineering controls every 6 months and as needed (relocation, alteration, etc.)
- Viable surface and air sampling every 6 months as detailed in salient characteristics