

**RFI FORM**

**Contractor Name:**

**Address:**

**Phone/Fax:**

**Send to:** [cecil.nichols@va.gov](mailto:cecil.nichols@va.gov)

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>		<b>RFI NO.:</b>	003
<b>PROJECT NAME:</b>	SERVICE to PERFORM Annual HVAC Systems Preventative Maint.	<b>DATE REQUESTED:</b>	01/11/2018
<b>SOLICITATION NO.:</b>	36C26218R0220	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible: LIST OF EQUIPMENT COVERED: Chillers – ten (10) air cool and water cool.  QUESTION: Can you please provide the make and model for each of the ten (10) chillers? QUESTION: Are all ten (10) chillers primary units, and if not, how many are primary units?			
<b>PROJECT MANAGER'S RESPONSE</b>			
They are York chillers (YKM2MRH9-CWGS (3). YKKPK4H9-CXG (1). CARRIER 30GXR135-A-650KA (1). TRANE CGAFC204ALA1(1) TRANE (1). TEAM AIRCAH18000D (1) CARRIER (1), Daikins (1) All are primary at any time they can be secondary.			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>  KENNETH W. MARSHALL, HVAC Mechanic, VA Loma Linda		<b>DATE:</b>  1/18/2018	