



GENERAL NOTES

1. REFER TO SPECIFICATIONS DIVISION 01 GENERAL REQUIREMENTS.
2. REFER TO DRAWING G-004 FOR PROJECT CONSTRUCTION PHASING NOTES.
3. REFER TO STRUCTURAL DRAWING S-100 FOR FOUNDATION LEVEL PLAN AND RELATED SCOPE OF WORK ITEMS.
4. REFER TO SPECIFICATIONS, APPENDIX D FOR EXISTING LIGHTNING PROTECTION SYSTEM - PHOTO INDEX AT EXISTING PARKING GARAGE LEVEL D.

DEMOLITION NOTES

1. PROVIDE TEMPORARY CONSTRUCTION BARRIERS AT EXISTING PARKING DECK LEVELS PRIOR TO STARTING DEMOLITION ACTIVITIES. REFER TO DRAWING AD-103 FOR TYPICAL TEMPORARY CONSTRUCTION BARRIERS DETAILS.
2. EXISTING CONCRETE FOUNDATION SYSTEM PROFILE LINES. REFER TO STRUCTURAL DRAWING S-101 FOR INFORMATION ON EXISTING ELEVATIONS.
3. EXISTING DRAIN TILE INSTALLED ALONG EXISTING EXTERIOR FOUNDATION WALL FACE/LINE SHALL BE REMOVED. REFER TO PLUMBING DRAWING P-101 FOR ADDITIONAL NOTES.
4. REFER TO DRAWING A-502 FOR MASONRY RESTORATION WORK AT THIS WALL AREA - LEVEL D, EXISTING.
5. DISCONNECT LIGHTNING PROTECTION COPPER CABLING CONNECTION PLATE AND SEALANT SYSTEM AT EXISTING ALUMINUM RAILING SYSTEM AT LEVEL D. TYPICAL FOR ALL ALUMINUM RAILING SYSTEMS AT LEVEL D.
6. DISCONNECT EXISTING LIGHTNING PROTECTION COPPER CABLING, CONNECTION PLATE AND AIR TERMINALS AT EXISTING CONCRETE COLUMNS. TYPICAL FOR ALL CONCRETE COLUMNS AT LEVEL D.
7. ORIGINAL 4-INCH FACE BRICK VENEER AT CONCRETE COLUMNS WAS NOT INSTALLED. REFER TO AD-201.
8. EXISTING FACE BRICK VENEER WALL CONSTRUCTION TO REMAIN.
9. REMOVE EXISTING PRECAST CONCRETE SPANDREL PANEL. REMOVE SEALANT SYSTEM AT VERTICAL JOINT.
10. PROTECT ALL ALUMINUM RAILING SYSTEMS DURING ALL CONSTRUCTION ACTIVITIES.
11. EXISTING PRECAST CONCRETE COLUMNS AT LEVEL D.
12. REMOVE EXISTING PRECAST CONCRETE WALL PANEL AND COPINGS AT THIS WALL AREA. APPROXIMATE LENGTH IS 33'-0".
13. REMOVE COPPER LIGHTNING PROTECTION CABLING SYSTEM AT TOP OF WALL FROM COLUMN LINE 16 TO 18 OF EXISTING PARKING GARAGE AT LEVEL D. REFER TO DRAWING E-106 FOR ADDITIONAL INFORMATION.
14. CONTRACTOR SHALL NOTE THAT COPPER LIGHTNING PROTECTION CABLING IS INSTALLED BEHIND THE FACE BRICK VENEER WALL CONSTRUCTION. CONTRACTOR SHALL REMOVE AND REINSTALL AS REQUIRED BY FIELD CONDITIONS.