

BUILDING ISOMETRIC


GENERAL NOTES




1. REFER TO DRAWING FP-001 FOR ABBREVIATIONS, SYMBOLS LIST AND TYPICAL DETAILS.
2. REFER TO DRAWING FP-002 FOR EXISTING FIRE PROTECTION SYSTEM PIPING ARRANGEMENT.
3. REFER TO SPECIFICATIONS DIVISION 01 GENERAL REQUIREMENTS.
4. REFER TO DIVISION 21 FIRE SUPPRESSION FOR PROJECT REQUIREMENTS.
5. REFER TO DRAWING G-004 FOR PROJECT CONSTRUCTION PHASING NOTES.

FIRE PROTECTION NOTES

1. EXISTING DRY STANDPIPE RISER LOCATION AT EXISTING STAIR UNIT 2 TO REMAIN.
2. EXISTING 4" UP TO LEVEL B DRY STAND PIPE RISER AT COLUMN LINE 15 AND D HAS A FUTURE CONNECTION POINT FOR OUR FIRE PROTECTION PIPING INTERCONNECTION.
3. CONNECT FIRE PROTECTION PIPING AT THIS LOCATION.
4. FIRE PROTECTION PIPING ROUTE. REFER TO ARCHITECTURAL BUILDING SECTIONS FOR STRUCTURAL FRAMING SYSTEMS.
5. FIRE PROTECTION PIPING INSTALLED BELOW EXISTING STRUCTURAL FRAMING SYSTEM.
6. FIRE PROTECTION PIPING INSTALLED BETWEEN THE PARKING DECK CONCRETE DOUBLE TEE MEMBERS. REFER TO ARCHITECTURAL BUILDING SECTIONS FOR EXISTING DOUBLE TEE SPACING/DIMENSIONS.
7. FIRE PROTECTION PIPING INSTALLED BELOW EXISTING CONCRETE DOUBLE TEE MEMBERS. INSTALL AS TIGHT AS POSSIBLE TO UNDERSIDE OF EXISTING CONCRETE STEMS.
8. FIRE PROTECTION PIPING UP/DOWN POINTS.
9. DIMENSIONS INDICATED ARE APPROXIMATE. CONTRACTOR SHALL PROVIDE SHOP DRAWING INDICATING FINAL FIRE PROTECTION SYSTEM PIPING LOCATIONS.
10. 4" FP DRY STAND PIPE, 2-1/2" REDUCER, 2-1/2" VALVE AND CAP FOR FIRE HOSE CONNECTION.
11. 4" FP DRY STAND PIPE UP TO LEVEL BB. REFER TO DRAWING FP-102 FOR CONTINUATION.

1 LEVEL A - FIRE PROTECTION PLAN  
3/32"=1'-0"



		CONSULTANTS:		KEYPLAN ⊕		ARCHITECT + ENGINEERS:		Drawing Title LEVEL A - FIRE PROTECTION PLAN		Project Title CONSTRUCT NORTH PARKING STRUCTURE		Project Number 506-331		Office of Construction and Facilities Management <div>Department of Veterans Affairs</div>	
		<div> <b>WALKER</b> PARKING CONSULTANTS 225 Andy Drive, Suite 1 Ann Arbor, MI 48108</div> <div> <b>MIDWESTERN</b> CONSULTING 3815 Plaza Drive Ann Arbor, Michigan 48108 (734) 995-0200 • www.midwesternconsulting.com Land Development • Land Survey • Institutional • Municipal Wireless Communications • Transportation • Landfill Services</div>				<div> BANCROFT ARCHITECTS + ENGINEERS 700 Nicholas Blvd., Suite 300 Elk Grove Village, IL 60007 Telephone : 847.952.9342 www.bancroft-ae.com Bancroft-AE Project No. 14-121</div> <div>VA CONTRACT NO. VA250-17-C-0008</div>		Approved Project Director		Location ANN ARBOR, MICHIGAN		Building Number 29			
100% FINAL BID DOCUMENTS 08-18-2017								Date 08-18-2017		Checked EM		Drawing Number FP-101			
100% BID DOCUMENTS-NOT FOR CONSTRUCTION 07-24-2017															
95% CONSTRUCTION DOCUMENTS SUBMISSION 06-15-2017															
65% DESIGN DEVELOPMENT SUBMISSION 04-19-2017															
35% SCHEMATIC DESIGN SUBMISSION 03-06-2017															
Revisions															
Date															