



BUILDING ISOMETRIC

GENERAL NOTES

1. REFER TO DRAWING FP-001 FOR ABBREVIATIONS, SYMBOLS LIST AND TYPICAL DETAILS.
2. REFER TO DRAWING FP-002 FOR EXISTING FIRE PROTECTION SYSTEM PIPING ARRANGEMENT.
3. REFER TO SPECIFICATIONS DIVISION 01 GENERAL REQUIREMENTS.
4. REFER TO DIVISION 21 FIRE SUPPRESSION FOR PROJECT REQUIREMENTS.
5. REFER TO DRAWING G-004 FOR PROJECT CONSTRUCTION PHASING NOTES.
6. REFER TO FIRE PROTECTION ISOMETRIC ON SHEET FP-001 FOR ADDITIONAL INFORMATION.

FIRE PROTECTION NOTES

1. EXISTING DRY STANDPIPE RISER LOCATION AT EXISTING STAIR 2 TO REMAIN.
2. EXISTING DRY STAND PIPE RISER TO REMAIN 4" DOWN TO LEVEL C.
3. 4" FP DRY STAND PIPE, 2-1/2" REDUCER, 2-1/2" VALVE AND CAP FOR FIRE HOSE CONNECTION.
4. 4" FP DRY STAND PIPE, DOWN TO LEVEL CC AND UP TO LEVEL EE. REFER TO DRAWING FP-103 AND FP-105 FOR CONTINUATION.

1 LEVEL D - FIRE PROTECTION PLAN  
3/32"=1'-0"

<b>CONSULTANTS:</b>  WALKER PARKING CONSULTANTS 225 Andy Drive, Suite 1 Ann Arbor, MI 48108		<b>KEYPLAN</b>		<b>ARCHITECT + ENGINEERS:</b>  BANCROFT ARCHITECTS + ENGINEERS 700 Nicholas Blvd., Suite 300 Eli Grove Village, IL 60007 Telephone : 847.952.9342 www.bancroft-ae.com Bancroft-AE Project No. 14-121 VA CONTRACT NO. VA250-17-C-0008		<b>Drawing Title</b> LEVEL D - FIRE PROTECTION PLAN		<b>Project Title</b> CONSTRUCT NORTH PARKING STRUCTURE		<b>Project Number</b> 506-331		<b>Office of Construction and Facilities Management</b> 
<b>100% FINAL BID DOCUMENTS</b> 08-18-2017 <b>100% BID DOCUMENTS-NOT FOR CONSTRUCTION</b> 07-24-2017 <b>95% CONSTRUCTION DOCUMENTS SUBMISSION</b> 06-15-2017 <b>65% DESIGN DEVELOPMENT SUBMISSION</b> 04-19-2017 <b>35% SCHEMATIC DESIGN SUBMISSION</b> 03-06-2017 <b>Revisions:</b> Date						<b>Approved Project Director</b>		<b>Location</b> ANN ARBOR, MICHIGAN		<b>Building Number</b> 29		
								<b>Date</b> 08-18-2017		<b>Checked</b> EM		