

BUILDING ISOMETRIC




GENERAL NOTES

1. REFER TO DRAWING FP-001 FOR ABBREVIATIONS, SYMBOLS LIST AND TYPICAL DETAILS.
2. REFER TO DRAWING FP-002 FOR EXISTING FIRE PROTECTION DRAWINGS.
3. REFER TO SPECIFICATIONS DIVISION 01 GENERAL REQUIREMENTS.
4. REFER TO DIVISION 21 FIRE SUPPRESSION FOR PROJECT REQUIREMENTS.
5. REFER TO DRAWING G-004 FOR PROJECT CONSTRUCTION PHASING NOTES.
6. REFER TO FIRE PROTECTION ISOMETRIC ON SHEET FP-001 FOR ADDITIONAL INFORMATION.

FIRE PROTECTION NOTES

1. EXTEND FIRE PROTECTION DRY STANDPIPE DOWN TO LEVEL D AND CONNECTION TO EXISTING FIRE PROTECTION RISER PIPE.
2. 4" FP DRY STAND PIPE, 2-1/2" REDUCER, 2-1/2" VALVE AND CAP FOR FIRE HOSE CONNECTION.
3. 4" FP DRY STAND PIPE, DOWN TO LEVEL DD. REFER TO DRAWING FP-104 FOR CONTINUATION.

1 LEVEL E - FIRE PROTECTION PLAN
3/32"=1'-0"
PLAN NORTH

		CONSULTANTS:		KEYPLAN		ARCHITECT + ENGINEERS:		Drawing Title LEVEL E - FIRE PROTECTION PLAN		Project Title CONSTRUCT NORTH PARKING STRUCTURE		Project Number 506-331		Office of Construction and Facilities Management			
		 										Building Number 29					
100% FINAL BID DOCUMENTS 08-18-2017		100% BID DOCUMENTS-NOT FOR CONSTRUCTION 07-24-2017										Drawing Number FP-105					
95% CONSTRUCTION DOCUMENTS SUBMISSION 06-15-2017		65% DESIGN DEVELOPMENT SUBMISSION 04-19-2017		MIDWESTERN CONSULTING 3815 Plaza Drive Ann Arbor, Michigan 48108 (734) 995-0200 • www.midwesternconsulting.com Land Development • Land Survey • Institutional • Municipal Wireless Communications • Transportation • Landfill Services		BANCROFT ARCHITECTS + ENGINEERS 700 Nicholas Blvd., Suite 300 Elk Grove Village, IL 60007 Telephone : 847.952.9342 www.bancroft-ae.com Bancroft-AE Project No. 14-121		Approved Project Director		Location ANN ARBOR, MICHIGAN		Date 08-18-2017		Checked EM		Drawn AG	
65% DESIGN DEVELOPMENT SUBMISSION 04-19-2017		35% SCHEMATIC DESIGN SUBMISSION 03-06-2017															
Revisions:		Date															