



BUILDING ISOMETRIC

GENERAL NOTES

- REFER TO SPECIFICATIONS DIVISION 01 GENERAL REQUIREMENTS.
- REFER TO SPECIFICATIONS DIVISION 26 ELECTRICAL, DIVISION 27 COMMUNICATIONS AND DIVISION 28 ELECTRONIC SAFETY AND SECURITY FOR PROJECT SPECIFICATIONS AND REQUIREMENTS.
- REFER TO DRAWING G-004 FOR PROJECT CONSTRUCTION PHASING NOTES.
- REFER TO DRAWING S-515, DETAIL 1-TYPICAL P/C TEE DETAIL FOR DOUBLE TEE STEM BLOCKOUT LOCATIONS AND QUANTITIES FOR CONDUIT ROUTING.
- REFER TO DRAWING E-001 FOR GENERAL ELECTRICAL NOTES, ELECTRICAL SYMBOLS LIST AND ABBREVIATIONS.
- REFER TO DRAWING ED-101 FOR ELECTRICAL DEMOLITION PLANS.
- REFER TO DRAWINGS E-101 THROUGH E-105 FOR ELECTRICAL LIGHTING AND POWER SYSTEM PLANS.
- CONDUIT ROUTING IS SHOWN DIAGRAMMATICALLY ON FLOOR PLANS. CONTRACTOR WILL PROVIDE SHOP DRAWING INDICATING ROUTING OF ALL CONDUIT SYSTEMS PRIOR TO INSTALLATION. REFER TO DETAIL 1 ON S-515 FOR THE LOCATION AND QUANTITIES OF BLOCKOUTS AT THE PRECAST DOUBLE TEE MEMBERS.

FIRE ALARM PLAN NOTES

- FIRE ALARM PULL STATION.
- FIRE ALARM AUDIO/VISUAL DEVICE.
- SUSPENDED SECURITY CAMERA LOCATION.
- EMERGENCY COMMUNICATION CONDUIT/CABLE DOWN TO ECS-2 PEDESTAL MOUNTED AT LEVEL A.
- SUSPENDED SECURITY CAMERA SYSTEM. IT SHOULD BE CIRCUITED TO PANEL 29 ER2-02.
- CONTRACTOR WILL NOTE THAT EXISTING SECURITY SYSTEM CONDUITS AND ASSOCIATED JUNCTION BOXES ARE CURRENTLY INSTALLED WITHIN EXISTING PARKING GARAGE. THESE CONDUITS, JUNCTION BOXES AND ALL ASSOCIATED HANGERS AND ANCHOR ASSEMBLIES WILL BE REMOVED.
- CONTRACTOR WILL REMOVE EXISTING SECURITY SYSTEM RISER CONDUITS THAT ARE ROUTED TO LEVEL B. CONDUIT RISERS ARE INSTALLED AT COLUMN LINES C-15 AND D-15. ABANDONED DECK OPENINGS WILL BE PROVIDED WITH A SEALANT SYSTEM.
- ALL FIRE ALARM SYSTEM CONDUITS WILL BE PROVIDED IN PREFINISHED COLOR, RED. CONDUITS WILL BE MINIMUM 3/4" (19MM) DIAMETER.

1 LEVEL B - COMMUNICATION, SURVEILLANCE AND FIRE ALARM
 3/32"=1'-0"
 PLAN NORTH

Scale: three eighths inch = one foot
 three quarters inch = one foot
 one half inch = one foot
 one quarter inch = one foot
 one eighth inch = one foot
 one sixteenth inch = one foot

100% FINAL BID DOCUMENTS	08-18-2017
100% BID DOCUMENTS-NOT FOR CONSTRUCTION	07-24-2017
95% CONSTRUCTION DOCUMENTS SUBMISSION	06-15-2017
65% DESIGN DEVELOPMENT SUBMISSION	04-19-2017
35% SCHEMATIC DESIGN SUBMISSION	03-06-2017
Revisions:	Date

CONSULTANTS:

WALKER PARKING CONSULTANTS
 225 Park Street, Suite 11
 Ann Arbor, MI 48108

MIDWESTERN CONSULTING
 3815 Plaza Drive Ann Arbor, Michigan 48108
 (734) 995-0200 • www.midwesternconsulting.com
 Land Development • Land Survey • Institutional • Municipal
 Wireless Communications • Transportation • Landfill Services

KEYPLAN

ARCHITECT + ENGINEERS:

BANCROFT ARCHITECTS + ENGINEERS
 700 Nicholas Blvd., Suite 300
 Elk Grove Village, IL 60007
 Telephone: 847.952.9342
 www.bancroft-ae.com
 Bancroft-AE Project No. 16-121
 VA CONTRACT NO. VA250-17-C-0008

Drawing Title LEVEL B - COMMUNICATION, SURVEILLANCE AND FIRE ALARM PLAN	Approved Project Director
---	----------------------------------

Project Title CONSTRUCT NORTH PARKING STRUCTURE	Project Number 506-331
Location ANN ARBOR, MICHIGAN	Building Number 29
Date 08-18-2017	Checked LF
Drawn YY AG	Drawing Number EC-102

Office of Construction and Facilities Management

Department of Veterans Affairs