

September 1, 2017

Re: Buffalo VA Medical Center – Consolidate Surgical Programs
3495 Bailey Avenue
Buffalo, New York 14215
VA No. 528-12-373
KA No. 2012032

ADDENDUM No. 1

General:

All bidders submitting proposals for the above named project shall take note of the following changes, additions, interpretations, clarifications, etc., in connection with the drawings and project manual. The following instructions shall take precedence over anything contrarily shown on the drawings or described in the project manual, and as such shall be taken into consideration and be included in the bidders proposal. All requirements of the original drawings and project manual shall remain in force except as noted by this addendum. Bidders shall acknowledge receipt of this addendum by inserting its number and date in the space provided in the proposal form. Failure to do so may subject bidder to disqualification.

This Addendum No. 1 consists of 1 pages, plus 0 attachments.

DRAWINGS

Item No. 1 SS100 – Basement / Foundation Plan

- A. REVISE: Top of concrete caisson elevation in Drawing SS100 note #2 to (-16'-5").

Item No. 2 SS100 – Basement / Foundation Plan

- A. REVISE: Top of concrete tie beams along column lines A & 3 to (-12'-11").

Item No. 3 SS100 – Basement / Foundation Plan

- A. REVISE: Top of concrete tie beams along column lines F & 3 to (-12'-11").

END OF ADDENDUM NO. 1