

**REQUEST FOR INFORMATION (RFI)
VA250-17-R-0594**

| | | |
|-------------------|--|---|
| PROJECT NUMBER: | 583-331 | Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner. |
| PROJECT TITLE: | Specialty Care Clinic | |
| PROJECT LOCATION: | Department of Veterans Affairs RLR VA Medical Center 1481 W. 10 th Street Indianapolis, IN 46202 | |

| | | | |
|---------------|----------------------|-------------|--------------|
| SUBMITTED BY: | Armcorp Construction | CITY/STATE: | Celina, Ohio |
| PHONE: | 419-778-7024 | | |

TO:
 Felecia Beamen, Contracting Officer
 Department of Veterans Affairs
 Network 10 Contracting Office
 8888 Keystone Crossing, Suite 1100
 Indianapolis, IN 46240
Felecia.Beamen@va.gov

| | | |
|------------------|----------------|-------------------------|
| RFI NO.: | DATE: 12/20/17 | SPEC/DWG. REFERENCE(s): |
| REPLY NEEDED BY: | | |

INFORMATION NEEDED:

Will the Spec requiring the steel fabricator to be AISC certified be waived if the VA receives documentation that shows the fabricator meets or exceeds the AISC requirements?

REPLY:

RFI's will be answered by amendment(s) posted to fbo.gov.

No waiver, AISC certification shall remain a requirement.

| | |
|-----------------------------|------------------|
| REPLY FROM: Fred Fackenthal | DATE: 12/22/2017 |
| ATTACHMENTS: | COPY TO: |