

**REQUEST FOR INFORMATION (RFI)
VA250-17-R-0594**

PROJECT NUMBER:	583-331	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Specialty Care Clinic	
PROJECT LOCATION:	Department of Veterans Affairs RLR VA Medical Center 1481 W. 10 th Street Indianapolis, IN 46202	

SUBMITTED BY:	Armcorp Construction, Inc.	CITY/STATE:	Celina, Ohio
PHONE:	419-778-7024		

TO:
 Felecia Beamen, Contracting Officer
 Department of Veterans Affairs
 Network 10 Contracting Office
 8888 Keystone Crossing, Suite 1100
 Indianapolis, IN 46240
Felecia.Beamen@va.gov

RFI NO.:	DATE:	SPEC/DWG. REFERENCE(s):
REPLY NEEDED BY:		

INFORMATION NEEDED:

Will existing building 5 need sprinkler system added during construction of addition?

REPLY:

RFI's will be answered by amendment(s) posted to fbo.gov.

No, we are providing a 2-hr separation between buildings.

REPLY FROM: Fred Fackenthal, American Structurepoint	DATE: 1/19/2018
ATTACHMENTS:	COPY TO: