

**REQUEST FOR INFORMATION (RFI)
VA250-17-R-0594**

| | | |
|---------------------------------------|--|---|
| PROJECT NUMBER: | 583-331 | Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner. |
| PROJECT TITLE: | Specialty Care Clinic | |
| PROJECT LOCATION: Indianapolis, IN | Department of Veterans Affairs RLR VA Medical Center 1481 W. 10 th Street Indianapolis, IN 46202 | |

| | | | |
|---------------|------------------------------------|-------------|---------------|
| SUBMITTED BY: | Berkel & Company Contractors, Inc. | CITY/STATE: | La Grange, KY |
| PHONE: | 502-225-0053 | | |

TO:
 Felecia Beamen, Contracting Officer
 Department of Veterans Affairs
 Network 10 Contracting Office
 8888 Keystone Crossing, Suite 1100
 Indianapolis, IN 46240
Felecia.Beamen@va.gov

| | | |
|------------------|-----------------|--|
| RFI NO.: 2 | DATE: 1/10/2018 | SPEC/DWG. REFERENCE(s): Drawing Number 5-SS-310 typical auger cast pile detail |
| REPLY NEEDED BY: | | |

INFORMATION NEEDED:

1. On Structural Drawing 5-SS-310 please indicate if the center bar for both the PL16 pile and the PL16LAT pile has a hook at the top (what degree hook if so), a buttonhead, or hex nut and washer.

REPLY:

RFI's will be answered by amendment(s) posted to fbo.gov.

At contractor's option, it is acceptable to omit the hook for the center bar.

| | |
|---|--------------------|
| REPLY FROM: Fred Fackenthal, American Structurepoint | DATE: 1/19/2018 |
| ATTACHMENTS: | COPY TO: |