

**REQUEST FOR INFORMATION (RFI)  
VA250-17-R-0594**

PROJECT NUMBER:	583-331	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Specialty Care Clinic	
PROJECT LOCATION:	Department of Veterans Affairs RLR VA Medical Center 1481 W. 10 <sup>th</sup> Street Indianapolis, IN 46202	

SUBMITTED BY:	Patrick Broderick	CITY/STATE:	Louisville, KY
PHONE:	502-489-7676		

**TO:**  
 Felecia Beamen, Contracting Officer  
 Department of Veterans Affairs  
 Network 10 Contracting Office  
 8888 Keystone Crossing, Suite 1100  
 Indianapolis, IN 46240  
[Felecia.Beamen@va.gov](mailto:Felecia.Beamen@va.gov)

RFI NO.: 11	DATE: 01-17-18	SPEC/DWG. REFERENCE(s):
REPLY NEEDED BY:		

**INFORMATION NEEDED:**

At the site visit coordination drawings were discussed. Please clarify the VA's expectations regarding coordination drawings.

**REPLY:**

**RFI's will be answered by amendment(s) posted to fbo.gov.**

Coordination drawings should show that all utility systems can be installed without conflicts between systems and ceilings and can be installed in an orderly, organized manner.

REPLY FROM: <a href="#">Fred Fackenthal, American Structurepoint</a>	DATE: 1/18/2018
ATTACHMENTS:	COPY TO: