



CONTRACTOR'S NAME AND ADDRESS SEED Joint Venture 607 Arbor Circle Lakemoor, IL 60051	11/9/15	SPEC. SECTION 03 30 00
	STATION LOCATION Tomah , WI.	
	CONTRACT NUMBER VA69D-14-C-0190	PROJECT NUMBER. 676-322
	TRANSMITTAL DATE 10/12/15	TRANSMITTAL NO. 28R4

FORM OF SUBMITTAL					
<input type="checkbox"/> LETTER OF AFFIDAVIT OF COMPLIANCE	<input type="checkbox"/> SHOP DRAWINGS	<input checked="" type="checkbox"/> DATA SHEETS	<input type="checkbox"/> BROCHURE	<input type="checkbox"/> PHYSICAL SAMPLE	
<input type="checkbox"/> MANUFACTURER'S LITERATURE OR CATALOG CUTS	<input type="checkbox"/> TEST REPORTS	<input type="checkbox"/> OTHER 50% Design			

DEPARTMENT OF VETERANS AFFAIRS ACTION


NUMBER OF COPIES RETURNED Electronic
--

AUTHORITY FOR APPROVAL/DISAPPROVAL (Check applicable box)					
<input type="checkbox"/> APPROVED	<input checked="" type="checkbox"/> APPROVED AS NOTED	<input type="checkbox"/> REJECTED; RESUBMIT	<input type="checkbox"/> NO ACTION	<input type="checkbox"/> NO ACTION TAKEN RESUBMIT	

REASON FOR DISAPPROVAL OR REMARKS Corrective action approved as noted along with the additional repair areas that need correcting as shown in red clouded areas on attached drawing. Also need submittals for the bonding agent and concrete filler material prior to repairs.
--

SUBMITTALS ACTED UPON AND VA FILE NUMBERS ASSIGNED
(File numbers on disapproved submittals are for record purposes only.)

DESCRIPTION	SUPPLIER OR MANUFACTURER	VA FILE NUMBER
03 30 00 FF/FL Corrective Action Plan	Seed Joint Venture	676-322-28R4

SIGNATURE AND TITLE OF AUTHORIZING OFFICIAL  James E. Plimpton	DATE 11/9/15
--	------------------------



Date: 10-12-2015
Submittal No: 28R4
Description: T2- FF/FL Corrective Action
Submittal

Submittal Cover Sheet

Project Title

Construct Building for 75 Mental Health RRTP Beds

Project Number

676-322

Contract Number

VA69D-14-C-0190B

Project Location

Tomah VA Medical Center



SEED J.V. has conducted a cursory review of this submittal to ensure general conformance to the design and requirements of the contract documents. Final approval is the responsibility of the Architect and/or Engineer. Subcontractor and/or Vendor must verify dimensions, quantities and field conditions to ensure complete and proper installation of this work. Approval does not relieve Contractor or Supplier from responsibility due to installation errors, defects in workmanship or deviation from the contract documents.

Chris Wales



311 Glendale Avenue – Tomah, Wisconsin 54660

Phone: 608.343.8580

Fax: 608.372.5561

Email: t2-contractingllc@hotmail.com

Website: www.t2-contracting.com

10/12/15

Construct Building 405

Tomah, VA

To whom it may concern,

T2 Contracting's method of correction for concrete floors will be using a 10" floor grinder specific for this type of work. We will then use a ten foot straight edge as a guide to be able to feather the areas back into tolerance. Any questions or concerns please contact me.

Sincerely,

A handwritten signature in black ink that reads 'Eric Stickney'.

Eric Stickney - President

