



NOTES:

1. PLENUM AS SHOWN SHALL BE SUPPLIED BY MANUFACTURER OF FAN COIL UNIT.

2. SEE DETAIL FOR SUPPLY & RETURN PIPING CONNECTIONS.

SUPPLY & RETURN GRILLES SHALL BE SIZED TO SUIT CONNECTIONS ON FAN COIL UNIT. DUCTWORK SHALL SUIT GRILLES AND FAN COIL UNIT FURNISHED.

3.

4.

## FAN COIL UNIT - HORIZONTAL CONCEALED

NTS



Department of  
Veterans Affairs

DETAIL TITLE / 564-12-128 RENOVATE HIMs

SCALE :NONE

DATE ISSUED: 19-JUL-12

CAD DETAIL NO.: M-2